

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 05/01/2023 - 05/31/2023

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.7	Avg	9.7	Avg	9.6	
		Max	9.8	Max	9.9	Max	9.7	
		Min	9.7	Min	9.6	Min	9.5	
Total Alkalinity	mg/L as CaCO3	Avg	57	Avg	57	Avg	77	
		Max	64	Max	61	Max	81	
		Min	48	Min	49	Min	73	
Total Hardness	mg/L as CaCO3	Avg	94	Avg	95	Avg	105	
		Max	100	Max	100	Max	111	
		Min	86	Min	86	Min	100	
Total Solids	mg/L	Avg	210	Avg	225	Avg	225	
		Max	230	Max	230	Max	232	
		Min	198	Min	218	Min	214	
Total Chloramines	mg/L	Avg	2.73	Avg	2.44	Avg	2.66	
		Max	2.95	Max	2.75	Max	2.80	
		Min	2.55	Min	1.60	Min	2.55	
Total Organic Carbon	mg/L	Avg	2.68	Avg	2.60	Avg	2.66	
		Max	2.80	Max	2.73	Max	2.72	
		Min	2.51	Min	2.50	Min	2.61	
Conductivity	umhos/cm	Avg	357	Avg	366	Avg	397	
		Max	362	Max	366	Max	397	
		Min	352	Min	366	Min	397	
Total Trihalomethanes	ug/L	Avg	44.9	Avg	41.0	Avg	31.8	
		Max	46.9	Max	41.0	Max	31.8	
		Min	42.9	Min	41.0	Min	31.8	
Turbidity	NTU	Avg	.05	Avg	.02	Avg	.04	
		Max	.07	Max	.04	Max	.07	
		Min	.03	Min	.02	Min	.02	