

# City of Austin Water Quality Laboratory

## Drinking Water Quality Report

Samples Collected Between 08/01/2022 - 08/31/2022

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.7	Avg	9.6	Avg	9.6	
		Max	9.8	Max	9.8	Max	9.7	
		Min	9.7	Min	9.5	Min	9.6	
Total Alkalinity	mg/L as CaCO3	Avg	57	Avg	59	Avg	62	
		Max	63	Max	64	Max	65	
		Min	48	Min	50	Min	53	
Total Hardness	mg/L as CaCO3	Avg	86	Avg	89	Avg	87	
		Max	91	Max	94	Max	92	
		Min	76	Min	82	Min	82	
Total Solids	mg/L	Avg	189	Avg	207	Avg	198	
		Max	216	Max	214	Max	210	
		Min	178	Min	202	Min	184	
Total Chloramines	mg/L	Avg	2.77	Avg	2.59	Avg	2.76	
		Max	2.95	Max	2.80	Max	2.90	
		Min	2.60	Min	2.35	Min	2.65	
Total Organic Carbon	mg/L	Avg	2.38	Avg	2.23	Avg	2.16	
		Max	2.60	Max	2.36	Max	2.22	
		Min	2.21	Min	2.08	Min	2.10	
Conductivity	umhos/cm	Avg	315	Avg	313	Avg	352	
		Max	317	Max	313	Max	352	
		Min	313	Min	313	Min	352	
Total Trihalomethanes	ug/L	Avg	35.7	Avg	26.6	Avg	24.4	
		Max	36.4	Max	26.6	Max	24.4	
		Min	35.0	Min	26.6	Min	24.4	
Turbidity	NTU	Avg	.05	Avg	.02	Avg	.02	
		Max	.06	Max	.04	Max	.04	
		Min	.04	Min	.01	Min	.02	