

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 03/01/2021 - 03/31/2021

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP
pH	SU	Avg	9.6	Avg	9.6	Avg	9.6
		Max	9.7	Max	10.0	Max	9.7
		Min	9.6	Min	9.4	Min	9.5
Total Alkalinity	mg/L as CaCO3	Avg	69	Avg	68	Avg	77
		Max	77	Max	84	Max	87
		Min	61	Min	61	Min	73
Total Hardness	mg/L as CaCO3	Avg	101	Avg	100	Avg	102
		Max	110	Max	119	Max	113
		Min	95	Min	93	Min	97
Total Chloramines	mg/L	Avg	2.76	Avg	2.81	Avg	2.69
		Max	2.95	Max	3.05	Max	2.85
		Min	2.60	Min	2.65	Min	2.50
Total Organic Carbon	mg/L	Avg	2.55	Avg	2.33	Avg	2.46
		Max	2.70	Max	2.39	Max	2.55
		Min	2.45	Min	2.25	Min	2.37
Conductivity	umhos/cm	Avg	343	Avg	356	Avg	356
		Max	343	Max	356	Max	356
		Min	342	Min	356	Min	356
Total Trihalomethanes	ug/L	Avg	20.0	Avg	23.3	Avg	22.0
		Max	20.0	Max	23.3	Max	22.0
		Min	20.0	Min	23.3	Min	22.0
Turbidity	NTU	Avg	0.07	Avg	0.03	Avg	0.04
		Max	0.10	Max	0.08	Max	0.09
		Min	0.04	Min	0.03	Min	0.03

Due to Covid-19 the number of parameters analyzed has been reduced effective 3-27-20.