

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 05/01/2021 and 05/31/2021

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP
pH	SU	Avg	9.6	Avg	9.7	Avg	9.6
		Max	9.7	Max	10.0	Max	9.6
		Min	9.5	Min	9.3	Min	9.5
Total Alkalinity	mg/L as CaCO3	Avg	55	Avg	55	Avg	72
		Max	64	Max	60	Max	77
		Min	50	Min	52	Min	70
Total Hardness	mg/L as CaCO3	Avg	87	Avg	89	Avg	96
		Max	92	Max	92	Max	101
		Min	79	Min	86	Min	93
Total Chloramines	mg/L	Avg	2.74	Avg	2.81	Avg	2.71
		Max	2.85	Max	3.00	Max	2.85
		Min	2.65	Min	2.65	Min	2.60
Total Organic Carbon	mg/L	Avg	2.46	Avg	2.42	Avg	2.42
		Max	2.72	Max	2.56	Max	2.50
		Min	2.25	Min	2.28	Min	2.27
Total Trihalomethanes	ug/L	Avg	31.0	Avg	36.3	Avg	23.2
		Max	32.9	Max	36.3	Max	23.2
		Min	29.2	Min	36.3	Min	23.2
Turbidity	NTU	Avg	0.06	Avg	0.03	Avg	0.03
		Max	0.19	Max	0.07	Max	0.06
		Min	0.04	Min	0.02	Min	0.02

Due to Covid-19 the number of parameters analyzed has been reduced effective 03-27-20.