

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 04/01/2022 - 04/30/2022

Parameter	Units	Davis WTP		Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.7	Avg	9.7	Avg	9.6
		Max	9.7	Max	9.9	Max	9.7
		Min	9.6	Min	9.6	Min	9.6
Total Alkalinity	mg/L as CaCO3	Avg	63	Avg	62	Avg	73
		Max	67	Max	64	Max	81
		Min	58	Min	56	Min	64
Total Hardness	mg/L as CaCO3	Avg	94	Avg	93	Avg	96
		Max	98	Max	100	Max	105
		Min	86	Min	89	Min	88
Total Solids	mg/L	Avg	220	Avg	231	Avg	216
		Max	272	Max	266	Max	240
		Min	164	Min	180	Min	172
Total Chloramines	mg/L	Avg	2.86	Avg	2.70	Avg	2.73
		Max	3.10	Max	2.95	Max	2.85
		Min	2.65	Min	2.50	Min	2.60
Total Organic Carbon	mg/L	Avg	2.41	Avg	2.28	Avg	2.36
		Max	2.56	Max	2.34	Max	2.44
		Min	2.23	Min	2.20	Min	2.27
Conductivity	umhos/cm	Avg	334	Avg	333	Avg	352
		Max	345	Max	348	Max	360
		Min	323	Min	317	Min	344
Total Trihalomethanes	ug/L	Avg	26.6	Avg	28.0	Avg	24.6
		Max	27.6	Max	28.0	Max	24.6
		Min	25.6	Min	28.0	Min	24.6
Turbidity	NTU	Avg	.05	Avg	.03	Avg	.03
		Max	.08	Max	.11	Max	.05
		Min	.03	Min	.02	Min	.02