

# City of Austin Water Quality Laboratory

## Drinking Water Quality Report

Samples Collected Between 03/01/2023 - 03/31/2023

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.7	Avg	9.6	Avg	9.6	
		Max	9.7	Max	9.8	Max	9.6	
		Min	9.6	Min	9.4	Min	9.5	
Total Alkalinity	mg/L as CaCO3	Avg	70	Avg	64	Avg	85	
		Max	77	Max	70	Max	90	
		Min	61	Min	58	Min	82	
Total Hardness	mg/L as CaCO3	Avg	107	Avg	101	Avg	113	
		Max	114	Max	107	Max	117	
		Min	97	Min	94	Min	109	
Total Solids	mg/L	Avg	208	Avg	240	Avg	234	
		Max	234	Max	284	Max	256	
		Min	188	Min	208	Min	218	
Total Chloramines	mg/L	Avg	2.77	Avg	2.64	Avg	2.73	
		Max	3.00	Max	2.90	Max	2.85	
		Min	2.55	Min	2.40	Min	2.55	
Total Organic Carbon	mg/L	Avg	2.82	Avg	2.67	Avg	2.80	
		Max	3.01	Max	2.72	Max	2.85	
		Min	2.62	Min	2.62	Min	2.77	
Conductivity	umhos/cm	Avg		Avg	372	Avg	399	
		Max		Max	372	Max	399	
		Min		Min	372	Min	399	
Total Trihalomethanes	ug/L	Avg	29.1	Avg	23.2	Avg	19.2	
		Max	29.9	Max	23.2	Max	19.2	
		Min	28.2	Min	23.2	Min	19.2	
Turbidity	NTU	Avg	.06	Avg	.04	Avg	.04	
		Max	.07	Max	.07	Max	.06	
		Min	.04	Min	.02	Min	.03	