

Drinking Water Quality Report
Date Range: 01-AUG-2019 to 31-AUG-2019

Parameter	Units	Method Cd		Davis WTP T2,T2H		Ullrich WTP T3		WTP 4 T4
-----	----	-----		-----		-----		-----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.7	AVG	9.7
			MAX	9.9	MAX	9.9	MAX	9.7
			MIN	9.6	MIN	9.4	MIN	9.6
Total Alkalinity	MG/L	SM 2320 B	AVG	55	AVG	52	AVG	59
			MAX	60	MAX	55	MAX	64
			MIN	49	MIN	47	MIN	56
Total Hardness	MG/L	SM 2340 C	AVG	80	AVG	79	AVG	80
			MAX	86	MAX	82	MAX	85
			MIN	74	MIN	72	MIN	78
Total Solids	MG/L	SM 2540 B	AVG	143	AVG	134	AVG	152
			MAX	168	MAX	152	MAX	178
			MIN	132	MIN	126	MIN	138
Chloramines	MG/L	SM 4500-CL F	AVG	2.85	AVG	2.62	AVG	2.77
			MAX	3.05	MAX	2.85	MAX	2.95
			MIN	2.70	MIN	2.25	MIN	2.65
Sulfate	MG/L	SM 4500-SO4 E	AVG	31.4	AVG	23.8	AVG	27.6
			MAX	31.9	MAX	23.8	MAX	27.6
			MIN	30.9	MIN	23.8	MIN	27.6
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.57	AVG	2.38	AVG	2.42
			MAX	2.74	MAX	2.52	MAX	2.57
			MIN	2.33	MIN	2.16	MIN	2.29
Conductivity	UMHOS/cm	SM 2510 B	AVG	267	AVG	262	AVG	302
			MAX	269	MAX	262	MAX	307
			MIN	265	MIN	262	MIN	297
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	44.3	AVG	37.6	AVG	35.1
			MAX	51.2	MAX	39.1	MAX	35.9
			MIN	40.3	MIN	36.0	MIN	34.3
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.02	AVG	0.03
			MAX	0.09	MAX	0.04	MAX	0.05
			MIN	0.04	MIN	0.02	MIN	0.02