

**City of Austin Water Quality Laboratory**  
**Drinking Water Quality Report**

Samples Collected Between 12/1/2020 - 12/31/2020

Parameter	Units		Davis WTP		Ullrich WTP		WTP 4
pH	SU	<b>Avg</b>	9.6	<b>Avg</b>	9.6	<b>Avg</b>	9.6
		<b>Max</b>	9.7	<b>Max</b>	9.8	<b>Max</b>	9.6
		<b>Min</b>	9.5	<b>Min</b>	9.5	<b>Min</b>	9.5
Total Alkalinity	mg/L as CaCO3	<b>Avg</b>	70	<b>Avg</b>	65	<b>Avg</b>	70
		<b>Max</b>	76	<b>Max</b>	68	<b>Max</b>	72
		<b>Min</b>	66	<b>Min</b>	59	<b>Min</b>	67
Total Hardness	mg/L as CaCO3	<b>Avg</b>	99	<b>Avg</b>	94	<b>Avg</b>	93
		<b>Max</b>	106	<b>Max</b>	98	<b>Max</b>	95
		<b>Min</b>	94	<b>Min</b>	88	<b>Min</b>	90
Total Chloramines	mg/L	<b>Avg</b>	3.02	<b>Avg</b>	2.86	<b>Avg</b>	2.89
		<b>Max</b>	3.20	<b>Max</b>	3.00	<b>Max</b>	3.00
		<b>Min</b>	2.90	<b>Min</b>	2.75	<b>Min</b>	2.75
Total Organic Carbon	mg/L	<b>Avg</b>	2.66	<b>Avg</b>	2.55	<b>Avg</b>	2.41
		<b>Max</b>	2.80	<b>Max</b>	2.81	<b>Max</b>	2.49
		<b>Min</b>	2.55	<b>Min</b>	2.35	<b>Min</b>	2.34
Total Trihalomethanes	ug/L	<b>Avg</b>	26.3	<b>Avg</b>	29.6	<b>Avg</b>	26.4
		<b>Max</b>	26.4	<b>Max</b>	29.6	<b>Max</b>	26.4
		<b>Min</b>	26.2	<b>Min</b>	29.6	<b>Min</b>	26.4
Turbidity	NTU	<b>Avg</b>	0.07	<b>Avg</b>	0.04	<b>Avg</b>	0.03
		<b>Max</b>	0.09	<b>Max</b>	0.08	<b>Max</b>	0.07
		<b>Min</b>	0.05	<b>Min</b>	0.02	<b>Min</b>	0.02

Due to Covid-19 the number of parameters analyzed has been reduced effective 3-27-20.