Thursday, September 23, 2010

Austin Water Utility RECOMMENDATION FOR COUNCIL ACTION

Item No. 3

Subject: Approve Service Extension Request No. 2928 for wastewater service to 3009 Westlake Drive located within the Drinking Water Protection Zone and partially in the City's Limited Purpose Jurisdiction, to serve one single family house with an Estimated Peak Wet Weather Flow of 3 gallons per minute.

Amount and Source of Funding: There is no unanticipated fiscal impact.

Fiscal Note: A fiscal note is not required.

For More Information: Seyed Miri, P.E., 972-0202; Denise Avery, 972-0104

Boards and Commission Action: Recommended by the Environmental Board and the Water and

Wastewater Commission. Related to Items #2, 4, & 5.

3009 Westlake Dr. (the "Property") consists of approximately 3.42 acres of land on Lake Austin, approximately 70% of which is within the City of Austin full purpose jurisdiction and approximately 30% of which is within the City of Austin limited purpose jurisdiction. The owner of the Property, MICHAEL S. ISTRE, is proposing to construct an approximately 6,300 square foot single family house on the Property and requested that the City provide wastewater utility service to the Property as proposed in Service Extension Request No. 2928. The Property is within the Council approved Impact Fee Boundary, the Utility Service Area for wastewater, the Drinking Water Protection Zone and the Lake Austin Watershed.

The request for service does not include City cost participation or reimbursement. Based on the Water Utility's capacity analysis, adequate system capacity exists to meet the projected demands of the property to be served. The Estimated Peak Wet Weather Flow is projected at 3 gallons per minute. This request is being brought to the City Council because of Austin City Code § 25-9-35 that requires City Council approval for all Service Extension Requests in the Drinking Water Protection Zone that are not within the Austin Full Purpose Corporate Limits.

The Owner will construct approximately 100 feet of 8-inch gravity wastewater line from the City of Austin Westlake Drive #1 Lift Station east across Westlake Drive to the Property.

The proposed wastewater improvements will conform to all City of Austin Code requirements. The applicant will construct all required improvements at their cost and after final acceptance of construction, the applicant will dedicate the facilities to the City for ownership, operation and maintenance. The applicant has submitted a written request to be annexed by the City.

The Watershed Protection Department and other applicable City Departments have reviewed this Service Extension Request.