


**FIRE FLOW PROTECTION
TO BE PROVIDED BY
LOOP 360 WSC'S
12-INCH WATER LINE**

**STAFF PROPOSED
APPROXIMATELY 250 FEET
OF 8-INCH WATER LINE
Proposed 8-inch Water Line
NOT Suitable and Sufficient
for Project's Fire Flow
Requirement. Subject Tract
is within Travis County ESD
No. 9 Fire Protection Area.**



-  **Subject Tract**
-  Full-Purpose Jurisdiction
-  Limited-Purpose Jurisdiction
-  2-MILE ETJ

W. S.E.R. Name: 3011 Westlake Dr
W. S.E.R. Number: 2929