

## A G E N D A



## Recommendation for Council Action (Purchasing)

Austin City Council	Item ID:	7405	Agenda Number	76.
---------------------	----------	------	---------------	-----

Meeting Date:	June 23, 2011
---------------	---------------

Department:	Purchasing
-------------	------------

## Subject

Authorize award and execution of a 36-month requirements service contract with AIR CLEANING TECHNOLOGIES INC., Broken Arrow, OK to provide maintenance and repair of Plymovent exhaust systems in an estimated amount not to exceed \$135,000, with three 12-month extension options in an estimated amount not to exceed \$45,000 per extension option, for a total estimated contract amount not to exceed \$270,000.

## Amount and Source of Funding

Funding in the amount of \$9,333 is available in the Fiscal Year 2010-2011 Operating Budget of the Austin Fire Department. Funding in the amount of \$5,667 is available in the Fiscal Year 2010-2011 Operating Budget of the Emergency Medical Services Department. Funding for the remaining 32 months of the original contract period and extension options is contingent upon available funding in future budgets.

## Fiscal Note

There is no unanticipated fiscal impact. A fiscal note is not required.

Purchasing Language:	Sole Source.
----------------------	--------------

Prior Council Action:	
-----------------------	--

For More Information:	Colleen Athey, Buyer II, 972-4012
-----------------------	-----------------------------------

Boards and Commission Action:	
-------------------------------	--

MBE / WBE:	This contract will be awarded in compliance with Chapter 2-9C of the City Code (Minority-Owned and Women-Owned Business Enterprise Procurement Program). No subcontracting opportunities were identified; therefore, no goals were established for this solicitation.
------------	---

Related Items:	
----------------	--

## Additional Backup Information

This contract will provide inspection and repair services for all Plymovent systems installed in Austin Fire Department (AFD) and Emergency Medical Services (EMS) Department stations throughout the City of Austin. The Plymovent diesel exhaust system is used to remove diesel fumes and particulates produced by AFD and EMS vehicles housed in the stations.

The use of this system improves air quality, health conditions, and reduces maintenance and cleaning costs at the Fire and EMS stations.

The Plymovent brand vehicle emissions exhaust system has been installed in all new AFD and EMS stations since 1998. There are now a total of 50 locations that utilize this exhaust system.

Air Cleaning Technologies, Inc. is the sole authorized distributor of the Plymovent system in Texas, Oklahoma and Arkansas.