

ORDINANCE NO.

AN ORDINANCE AMENDING CITY CODE SECTION 25-12-133 RELATING TO MECHANICAL CODE REQUIREMENTS FOR ELECTRICAL CONNECTIONS.

BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF AUSTIN:

**PART 1.** City Code Section 25-12-133 (*Local Amendments to the Mechanical Code*) is amended to repeal Section 308.0 (*Electrical Connections*) and add a new Section 308.0 to read as follows:

**308.0 Electrical Connections.** Equipment regulated by this code requiring electrical connections of more than fifty volts shall have a positive means of disconnect adjacent to and in sight from the equipment served. A factory supplied disconnect switch or breaker that is an integral part of the mechanical equipment will satisfy this requirement. A 120 volt receptacle shall be located within twenty-five feet of the equipment for service and maintenance purposes. The receptacle shall be located on the same level as the equipment. Low-voltage wiring of fifty volts or less within a structure shall be installed in a manner to prevent physical damage.

**PART 2.** This ordinance takes effect on \_\_\_\_\_, 2011.

**PASSED AND APPROVED**

\_\_\_\_\_, 2011      § \_\_\_\_\_  
§ \_\_\_\_\_  
§ \_\_\_\_\_

Lee Leffingwell  
Mayor

**APPROVED:** \_\_\_\_\_

Karen Kennard  
City Attorney

**ATTEST:** \_\_\_\_\_

Shirley A. Gentry  
City Clerk