

**Recommendation for Council Action – Backup
Floodplain Variance Request – 4508 Speedway**

SUMMARY OF FINDINGS:

1. THE DEVELOPMENT DOES NOT CAUSE ADVERSE FLOODING ON OTHER PROPERTY. The applicant's engineer submitted technical data that indicates that the proposed development will not increase flood heights.
2. NO SAFE ACCESS. The depth of water at the proposed house will be 1.5 feet during the 100-year flood event and 1.1 feet during the 25-year flood event. The depth of water in the street in front of this property is 2.4 feet during the 100-year flood event and 2.1 feet during the 25-year flood event. First responder personnel do not have safe access to the house during a 100-year flood event.
3. ADDITIONAL OCCUPANCY IN THE FLOODPLAIN. The development increases the opportunity for human occupancy in the floodplain by increasing the conditioned area on the property in the form of adding a second bathroom and increasing the size of the kitchen and dining area. The development increases the conditioned living space within the 100-year floodplain from 847 square feet to 1,176 square feet.
4. PROPOSED FINISHED FLOOR ABOVE MINIMUM REQUIRED ELEVATION. The proposed addition will have its finished floor elevation above the City of Austin minimum elevation requirements, which require the finished floor elevation to be at least one foot above the 100-year floodplain elevation. The finished floor elevation of the proposed addition, which matches the finished floor of the existing structure, will be 2.1 feet above the 100-year floodplain.
5. HARDSHIP CONDITIONS FOR THE PROPERTY DO NOT EXIST. There is an existing 847 square foot house on the lot that meets freeboard requirements but not access requirements. Failure to grant a variance would not impact potential use of existing structure.

APPLICABLE CODE AND VARIANCES REQUESTED

- I. LDC Section 25-12-3, (Local Amendments to the Building Code), Section 1612.4.3 Means of Egress provides that normal access to a building shall be by direct connection with an area that is a minimum of one foot above the design flood elevation.

VARIANCE REQUESTED: *The applicant requests a variance to Building Code Section 1612.4.3, to allow an addition to a single-family building to be constructed without normal access, either vehicular or pedestrian, to an area that is a minimum of one foot above the design flood elevation. The entire lot is in the 100-year floodplain and partially in the 25-year floodplain. The depth of water in the street in front of this property is 2.4 feet during the 100-year flood event and 2.1 feet during the 25-year flood event.*

- II. LDC Section 25-12-3, (Local Amendments to the Building Code), Section G102.3 Nonconforming Uses prohibits expanding, changing, enlarging, or altering the use of a premises in a way which increases its nonconformity.

VARIANCE REQUESTED: *The applicant requests a variance to Building Code Section G102.3 to allow enlarging the total conditioned area on the property that does not have safe access out of the floodplain.*

- III. LDC Section 25-12-3, (Local Amendments to the Building Code), Section G102.3 Nonconforming Uses prohibits making a substantial improvement to a structure without changing the structure to conform to the floodplain regulations.

VARIANCE REQUESTED: *The applicant requests a variance to Building Code Section G102.3 to allow making a substantial improvement to the structure that does not have safe access out of the floodplain.*

- III. LDC Section 25-7-152 Dedication of Easements and Rights-of-Way requires that the owner of real property proposed to be developed dedicate to the public an easement or right-of-way for a drainage facility, open or enclosed, and stormwater flow to the limits of the 100-year floodplain.

VARIANCE REQUESTED: *The applicant requests a variance to exclude the footprints of the existing house, the addition, the deck, and shed from the requirement to dedicate a drainage easement to the full extent of the 100-year floodplain.*

- IV. LDC Section 25-7-92 (A) and (B) Encroachment on Floodplain Prohibited prohibits encroachment of a building on the 25-year and 100-year floodplains.

VARIANCE REQUESTED: *The applicant requests a variance to allow placement of a building within the 25-year and 100-year floodplains of Waller Creek.*

PREREQUISITES FOR GRANTING VARIANCES AND FINDINGS:

Per LDC Section 25-12-3, Technical Codes, Section G 105 Variances, variances shall only be issued upon consideration of the following prerequisites:

PREREQUISITE

1) A technical showing of good and sufficient cause based on the unique characteristics of the size, configuration or topography of the site.

Insufficient causes for issuing a variance may include the following:

- *Less than a drastic depreciation of property.*
- *Convenience of property owner.*

FINDING

1) **CONDITION IS NOT MET.** The applicant has not demonstrated a good and sufficient cause that justifies increasing density on this property where there is no safe access out of the floodplain.

- *Circumstances of owner not land.*
- *To obtain better financial return.*
- *Property similar to others in neighborhood.*
- *Hardship created by owner's own actions.*

2) A determination that failure to grant the variance would result in exceptional hardship by rendering the lot undevelopable;
The location of the floodplain on the property is a characteristic of the land. Hardship refers to the effect of the floodplain status of the land on its use; it does not refer to personal or financial circumstances of the current owner of the land. In fact financial hardship, inconvenience, aesthetic considerations, physical handicaps, personal preferences or the disapproval of one's neighbors do not qualify as exceptional hardships. The applicant has the burden of proving exceptional hardship. FEMA advises that the reasons for granting floodplain management variances must be substantial and the proof compelling. The claimed hardship must be exceptional, unusual and peculiar to the property involved.

3) A determination that granting of a variance would not result in increased flood heights, additional threats to public safety, extraordinary public expense, nor create nuisances, cause fraud on or victimization of the public or conflict with existing laws or ordinances.

4) A determination that the variance is the minimum necessary, considering the flood hazard, to afford relief.

Relief is defined as respite from unnecessary hardship. Unnecessary hardship is defined as:

- *Loss of all beneficial or productive use.*
- *Deprivation of reasonable return on property.*
- *Deprivation of all or any reasonable use.*
- *Rendering property valueless.*
- *Inability to develop property in compliance with the regulations.*
- *Reasonable use cannot be made consistent with the regulation.*

2) **CONDITION IS NOT MET.** There is a single-family dwelling currently on this lot. Failure to grant this variance would in no way preclude the existing single family use from being continued.

3) **CONDITION IS NOT MET.** The proposed development does not increase flood heights. The development does increase public safety threat because more occupants could be located in the house without safe access for the occupants and first responders.

4) **CONDITION IS NOT MET.** The property currently provides a reasonable use as a single-family residence. Increasing the conditioned area on the property by 39% is not considered the minimum necessary.

5) Notification to the applicant in writing over the signature of the building official that the issuance of a variance to construct a structure below the base flood level will result in increased premium rates for flood insurance, and that such construction below the base flood level increases risks to life and property.

5) **CONDITION IS MET.** The finished floor elevation of the proposed building will be 2.1 feet above the 100-year floodplain elevation.