

A G E N D A



Recommendation for Council Action

Austin City Council - Commissioner's Court Meeting		Item ID	34745	Agenda Number	7.
Meeting Date:	10/2/2014		Department:	Austin Water Utility	
Subject					
Approve Service Extension Request No. 3406 for water service to a 25.5 acre tract at 11900 Buckner Road located within the Drinking Water Protection Zone, the City's limited purpose jurisdiction, and Austin Water Utility's service area.					
Amount and Source of Funding					
There is no anticipated fiscal impact.					
Fiscal Note					
Purchasing Language:					
Prior Council Action:					
For More Information:	Phillip Jaeger, 972-0232; Denise Avery, 972-0104				
Boards and Commission Action:	July 16, 2014 - Recommended by the Environmental Board on a 5-1-0-1 vote with Commissioner Neely voting against and Commissioner Perales absent (Recommendation No. 20140716-006a). August 13, 2014 - Recommended by the Water and Wastewater Commission on a 4-2-0-1 vote with Commissioners Clark and Fishbeck voting against and Commissioner Lee absent (Recommendation No. 20140813-D7).				
MBE / WBE:					
Related Items:					
Additional Backup Information					
<p>The Stokes Ranch development (the "Property") consists of approximately 25.5 acres of land within the City of Austin's limited purpose jurisdiction. The Property is proposing to include approximately 36 single-family condominium units, 4,704 sq. ft. restaurant use and 21,562 sq. ft. retail use. HTK 620, LLC (the "Applicant") requested that the City provide water utility service to the Property as proposed in Service Extension Request No. 3406. The Property is located entirely within the City's Impact Fee Boundary, Austin Water's Service Area, the Drinking Water Protection Zone, and the Lake Travis Watershed. The Property fronts the City's full purpose corporate limits.</p> <p>City Code § 25-9-35 requires City Council approval for this Service Extension Request because the Property is located within the Drinking Water Protection Zone and outside the City's full purpose corporate limits.</p> <p>The City will not cost participate on this project. Based on Austin Water's capacity analysis, adequate system capacity exists to meet the projected demands of the Property, including the provision of fire flows. The estimated peak hour flow for the Property is projected at 161 gallons per minute.</p> <p>The Applicant shall construct approximately 1,000 feet of 12-inch water main from the existing 16-inch water main</p>					

on the east side of N FM 620 Road near Boulder Lane and extend west across N FM 620 Road, north along the Property frontage and then east across N FM 620 Road and connect back to the existing 16-inch water main on the east side of N FM 620 Road.

The proposed water improvements will conform to all City Code requirements. The Owner will construct all required improvements at his cost and dedicate the facilities to the City for ownership, operation and maintenance. All City fees are applicable to the provision of water service including capital recovery fees.

The site development is subject to current City Code, including the Watershed Protection Ordinance.