

**AWU draft language related to the  
Reclaimed Mandatory Connection Requirement  
found in the Conservation Ordinance 6-4**

**Version 1**

**601.1.3** All new commercial developments or redevelopments located within 250 feet of a reclaimed water distribution line are required to obtain and utilize permitted connections to reclaimed water for irrigation, cooling, and other applicable water uses.

Exception: Uses associated with law enforcement, public health, and public safety.

**601.1.3.1** When, after removing irrigation and cooling demands, a site requires a potable water meter of 2.0 inches or greater, the applicant shall shift all remaining applicable water use to the reclaimed water system. If the applicant is unable to shift all remaining water uses to the reclaimed system, the applicant will be required to demonstrate, by calculations, system process description, or other means, the reasons why reclaimed water cannot be used for the remaining water uses.

## **Version 2**

**601.1.3** All new commercial developments or redevelopments located within 250 feet of a reclaimed water distribution line are required to obtain and utilize permitted connections to reclaimed water for irrigation, cooling, and other applicable water uses.

Exception: Uses associated with law enforcement, public health, and public safety.

**601.1.3.1** Reclaimed water shall be used for other applicable water uses. If after removing irrigation and cooling demands, the site requires a potable water meter 2" or greater, there is likely other applicable water use on site that also shall be shifted to the reclaimed water system.