

An aerial photograph of the Starcke Dam in Austin, Texas. The water is extremely turbid, appearing as a thick, brownish-yellow slurry. Large plumes of white foam and spray are visible as the water cascades over the dam's spillways. The surrounding landscape includes green trees and some industrial structures on the left side of the river.

# October 2018 High Turbidity Event

## City Council Work Session

### December 11, 2018

Greg Meszaros, Director

Rick Coronado, Assistant Director

- Introduction
- Water Treatment Facilities Overview
- Timeline
- Water Quality Data
- Zebra Mussels

## ● Lake Travis Flows

- 375,000 cfs peak flow rate (2.7 million gallons/second)
- Equal to about 4.5 times Niagara Falls average flow rate

## ● Flooding Centered on Llano River

- Llano daily average streamflow was 168,000 cfs
- The largest from a river feeding into the Highland Lakes since the construction of Mansfield Dam




Figure shows daily average flow on the Llano River from 1939 to 2018



# Moved Floodwaters Through the Pass-Through Lakes – Down the River – to the Flood Pool at Lake Travis






Picture shows turbid water from Oct. 2018 flood entering Matagorda Bay

Barton Creek meets the turbid waters of the rain-swollen Lady Bird Lake on Tuesday October 23, 2018.  
[JAY JANNER/AMERICAN-STATESMAN]





Ullrich Raw Water Turbidity During Flooding Events





10/19/18 Event    10/26/15 Event    5/26/15 Event    10/30/13 Event    9/8/10 Event  
 11/17/04 Event    7/17/02 Event    11/16/01 Event    10/18/98 Event    7/1/97 Event


# Water Treatment Plant Overview

Plant	Built	Capacity	Sedimentation	Filtration	Other Technology
Handcox WTP	2014	50 MGD	2 upflow clarifiers	4 dual media filters w/ support underdrain	First AW WTP with On-Site Chlorine Generation
Ullrich WTP	1969 (w/multiple expansions)	167 MGD	7 upflow clarifiers	18 dual media filters w/ support underdrain (capacity expanded in 2003)	Recarbonation added in 1994
Davis WTP	1954 (w/multiple expansions)	118 MGD	9 conventional, straight flow basins	27 dual media filters with support gravel	Recarbonation added in 1994

## Two major components of the process are:

1. Disinfection (using Chlorine & Ammonia)
    - Destroy or Deactivate Pathogens
  2. Particle Removal (using Ferric Sulfate)
    - Coagulation  Flocculation  Sedimentation
- 
- Austin Water also *softens* the water by adding Lime ( $\text{CaO}$ )
    - Softening removes scale forming minerals such as calcium and magnesium
    - City of Austin has been lime softening since 1925





## **Considerations:**

- Source water quality
- Finished water quality goals
  - Regulatory (EPA, TCEQ)
  - Customer expectations (residential, commercial/industrial)
  - Distribution System Goals

Austin Water is working with a consultant to review options to enhance the current treatment technologies based on the water quality experienced and lessons learned.

- Initial testing includes providing jar testing with 100+ NTU water and polymer chemical treatment.


Austin Water contracted with two university professors to provide peer review of the testing results and recommendations.

- Timeline details are described in Memorandum to Council presented November 13, 2018, “October Boil Water Notification Timeline”.
- Additionally, the following graphical timeline presentation is annotated with significant events resulting in decisions to communicate information and cease the boil water advisory.



# Hourly Water Use, AW WTPs Production, & Water Quality

Last Updated: 11/08/18





Preliminary Under Review

# Hourly Water Use, AW WTPs Production, & Water Quality

Last Updated: 11/08/18


Millions of Gallons (MG) / Million Gallons per Day (MGD)



Preliminary Under Review

# Hourly Water Use, AW WTPs Production, & Water Quality


Last Updated: 11/08/18




# Hourly Water Use, AW WTPs Production, & Water Quality

Last Updated: 11/08/18

Millions of Gallons (MG) / Million Gallons per Day (MGD)




Last Updated: 11/08/18




WTP4 Shutdown Ullrich Shutdown Ullrich Raw Water Quality - Turbidity Water Use WTP Production Distribution Reservoir Storage Daily Rainfall (in.)



## Ullrich WTP Raw Water Quality Parameters (Daily Average)



## Ullrich Finished Water Turbidity



- All WTPs maintained a strong disinfection process
  - Average monthly disinfection residual of 2.33 mg/l
- Plant Inactivation Ratio (Reported) - October 2018
  - 3.0 for Giardia
  - 15 for Viruses
- Water samples were negative for any harmful bacteriological tests for over 66 samples

# Impact of Zebra Mussels - None

- Zebra mussels are a threat to impair the withdrawal of water from the lake through accumulation on intake structures and piping.
- None of the WTPs experienced any problems drawing water from the lakes during the high turbidity event.
- Because they are filter feeders, zebra mussels prefer an environment of less than 50 NTU, so the high turbidity likely had an adverse effect on them.