



KNOX PRODUCT ONLINE ORDER INSTRUCTIONS

STEP 1

Go to
www.knoxbox.com

STEP 2

Select product series
from
menu on left

STEP 3

Enter 'AUSTIN FIRE'
in Department Search
Field

STEP 4
'SELECT 'or
Click on this
button



STEP 5

Click on this
button to
continue

Proceed with
preauthorized order

STEP 6

Select product, enter
installation address,
proceed w/ eApproval.
You will get email w/
approval,
CHECKOUT



WITH TAMPER SWITCH

3200 Series KNOX-BOX:

Any color, surface mounted or recessed, hinged or lift off door, required on all buildings with a monitored alarm system and fire protection systems

****Part numbers: 3202-3275****

Mount according to manufacturer's instructions, 4-6 feet above finished surface at main entry or at riser room, in view of approaching Fire Crews.

Contact AFD to secure door & building keys.



KNOX PADLOCK

If manual gates are part of a fire lane or used for AFD entry

****Part numbers: 3770-72****

Incorporated into the locking mechanism, chain, or 'Married' to the property's padlock by Fire Inspector or Fire Crew.



KNOX Key Switch

Automatic gates used for AFD entry:

****Part number 3502****

is required to be mounted street side of any gate used for fire department entry.



KNOX FDC CAPS & PLUGS

Required by current Fire Code on all new construction.

Also required if FDC caps are missing or damaged on all buildings.

****Part numbers 3041-3043****

Installed by AFD or Sprinkler Tech.