

Cooling Tower Requirements for Evaporation Credit Loss:

1. Site Plan that includes the following:

- a) Location of main domestic meter
- b) Location of tower

2. MEP plan that includes the following:

A. Elevation Plan *Include The Details as Indicated in the drawing below*

- a) Tower Water Level Overflow Switch
- b) Make Up Water Line
- c) Make Up Water Meter
- d) Backflow Protection
- e) 16" Head For Blow Down Meter
- f) Blow Down Meter
- g) Tower Overflow Drain To Sanitary
- h) Floor Drain (If located out from under the tower, the area immediately around the drain must be dammed to prevent excess rainwater into the sanitary sewer.
- i) Water level Switch and Alarm

