



## AUSTIN WATER

### STANDARD PRODUCTS LIST

#### CHANGES SINCE THE LAST ISSUE

(This issue effective October 1, 2018)

<u>SPL NO.</u>	<u>DESCRIPTION OF CHANGE</u>
WW-27A	Revised Description to increase size of PVC restraint to 16". Revised Ford Uni-flange 1300 and 1390 to include 16" for PVC. Added allowable sizes for Smith-Blair products. Revised SIP EZPVCP and PTPVC to include 16".
WW-27C	Added Sigma MJ Fittings.
WW-227B	Added requirement for cleanouts and 4" for maintenance only to Description, updated Manufacturers, updated Product Identification by removing unused fittings, adding part numbers and clarifying which fittings are not included. Added reference to SPL WW-227B-1 and AW Standard 520-AW-01A in Description.
WW-227B-1	New SPL.
WW-243A	Combined requirements previously shown in Comment and Description and listed them together in Description. Added approved installers. Added explanation to Note 3.
WW-243B	Combined requirements previously shown in Comment and Description and listed them together in Description. Added approved installers. Added explanation to Note 3.
WW-243C	Combined requirements previously shown in Comment and Description and listed them together in Description, with updates including drilled outlet flange for pinned completion plug. Added approved installers. Added explanation to Note 3.
WW-243D	Combined requirements previously shown in Comment and Description and listed them together in Description, with updates including drilled outlet flange for pinned completion plug. Added approved installers. Added explanation to Note 3.

WW-462	<p>Revise Description to require 316 Stainless Steel and minimum pressure requirement of 250 psi.</p> <p>Update all products to meet the new requirements.</p> <p>Change G-A INDUSTRIES, INC. address to Cranberry Township, 16066 and the name to VAG-USA (GA Industries).</p> <p>Change APCO/VALVE AND PRIMER CORP to DEZURIK.</p> <p>Add CRISPIN to MULTIPLEX MFG. CO.</p> <p>Add Note 1.</p>
WW-622	<p>Revised EJ wastewater cleanout frame and cover from locking to non-locking style.</p> <p>Added Sigma wastewater cleanout frame and cover.</p>