



**CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
SWING CHECK VALVES, AIR CUSHIONED**

USING DEPARTMENT: Water Utility **ISSUED:** 07/01/87 **REVIEWED:** 10/01/12 **REVISED:** 10/01/12

PREPARED BY: Bill Flynn, P.E. **CITY STOCK NUMBER:**

DESCRIPTION: Valves Swing Check - having outside lever and weight, air cushioned. Copper alloy parts (bronze and brass) shall contain not over 16 percent zinc. Copper alloy UNS No. shall be shown on permanent external marking in addition to markings required by AWWA C508. Effective January 1, 2013, valves purchased for City forces shall be "lead free" and marked by stamping, etching, or casting "NL" in the main body or by other methods acceptable to City. Effective January 4, 2014, all valves must be "lead free."

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
07/01/87 Re-approval	G-A INDUSTRIES, INC. 9025 Marshall Rd. Mars, PA 16046	G.A. Fig. 250-D	W. Flynn
07/01/87	APCO VALVE & PRIMER CORP. 1420 S. Wright Blvd. Schaumburg, IL 60193	APCO Series 6000	W. Flynn

NOTE: