



**CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
IRON FULL-BODY MJ TAPPING SLEEVES**

USING DEPARTMENT: Water Utility **ISSUED:** 02/03/78 **REVIEWED:** 10/01/11 **REVISED:** 10/01/11

PREPARED BY: Bill Flynn, P.E. **CITY STOCK NUMBER:**

DESCRIPTION: Sleeves, Tapping, Cast Iron or Ductile Iron body, for use on Cast Iron, Ductile Iron, PVC, and AC pipe. Sleeves shall have split body that completely surrounds pipe. Sleeves shall have mechanical joint body and flanged outlet and shall include duck-tipped or plain MJ gaskets (as required), split MJ glands, side flange gaskets, and approved bolts and nuts. (See WW-488T)

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
11/09/82	MUELLER COMPANY 500 West Eldorado St. Decatur, IL 62525	H-615 for CI, DI, and PVC H-619 for AC	K. Flowers
11/09/82	CLOW CORPORATION P.O. Box 350 Oskaloosa, IA 52557	F-5205	K. Flowers
10/13/83	U.S. PIPE & FOUNDRY CO. P.O. Box 10406 Birmingham, AL 35202	U.S. Mechanical Joint Tapping Sleeve	K. Flowers
10/01/92	TYLER PIPE P.O. Box 2027 Tyler, TX 75710	Compact DI body used on DI pipe only	K. Flowers
10/01/03	AMERICAN FLOW CONTROL P.O. Box 2727 Birmingham, AL 35202-2727	Series 1004 for CI, DI, and PVC Series 2800C for CI, DI, and PVC Series 2800A for AC	R. Lamb

NOTE: 1. To be used only if indicated on AWU-approved drawings.