CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
DOUBLE STRAP SERVICE CLAMPS

USING DEPARTMENT: Water Utility **ISSUED:** 01/23/78 **REVIEWED:** 01/01/12 **REVISED:** 01/01/12

PREPARED BY: Bill Flynn, P.E. **CITY STOCK NUMBER:**

DESCRIPTION: Clamps, service (tapping sleeves) double-strap having 12-mil nylon-coated ductile iron saddle with flat stainless steel straps and stainless steel bolts. Sizes are 4" x ¾" through 12" x 2" for ductile iron pipe O.D. or asbestos cement pipe O.D. Shall conform to AWWA C800, where applicable.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
01/03/94	SMITH-BLAIR, INC. P.O. Box 5337 Texarkana, TX 75505	Series 317 See note below	W. Flynn
01/03/94	ROMAC INDUSTRIES, INC. 1064 Fourth Ave. South Seattle, WA 98134	Style 202NS See note below	W. Flynn
04/03/95	FORD METER BOX COMPANY P.O. Box 443 Wabash, IN 46992-0443	FC202 See note below	W. Flynn
01/03/94	POWERSEAL PIPELINE PRODUCTS, CO. 1619 Eastside Drive Wichita Falls, TX 76307	Series 3417 See note below	W. Flynn
01/02/96	MUELLER COMPANY 500 West Eldorado Street Decatur, IL 62525	DN2S Series DR2S Series See note below	R. Lamb
01/02/97	JCM INDUSTRIES, INC. P.O. Box 1220 Nash, TX 75569-1220	406 Coated Wide Body See note below	W. Flynn
10/01/03	DRESSER PIPING SPECIALTIES 41 Fisher Avenue Bradford, PA 16701	Style 291 See note below	R. Lamb
10/01/08	A.Y. McDONALD P.O. Box 508 Dubuque, IA 52004	Model 4856A	R. Lamb

NOTE:

1. Bolt opening on one side or both sides of body must fully enclose strap bolts.