



**CITY OF AUSTIN  
STANDARD PRODUCTS LIST  
for  
COMPACT DUCTILE IRON FITTINGS**

**USING DEPARTMENT:** Water Utility    **ISSUED:** 10/01/87    **REVIEWED:** 04/01/13    **REVISED:** 04/01/13

**PREPARED BY:** William Flynn, P.E.    **CITY STOCK NUMBER:**

**DESCRIPTION:** Fittings, Compact Ductile Iron complying with AWWA C153 in 4", 6", 8", 12", 16", 20" and 24" sizes. All fittings shall have markings cast on the body as required by AWWA C153. Fittings complying with AWWA C153 shall be asphalt coated and cement-mortar lined with asphaltic seal coat complying with AWWA C104, or fusion-bonded epoxy coated and lined (inside and outside) complying with AWWA C116. Fusion-bonded epoxy must be red and shall comply with requirements of NSF 61. (See SPL WW-27 for Ductile Iron Fittings complying with AWWA C110.)

<b>LISTING DATE</b>	<b>MANUFACTURER</b>	<b>PRODUCT IDENTIFICATION/COMMENT</b>	<b>APPROVAL</b>
07/01/98	TYLER PIPE CO. P.O. Box 2027 Tyler, TX 75710	All Series; no retainer glands	W. Flynn
01/02/98	US PIPE AND FOUNDRY CO. P.O. Box 10406 Birmingham, AL 35202	All Series	W. Flynn
10/01/97	A-1 FOUNDRY (China)/ SIGMA CORPORATION P.O. Box 300 Rt. 537 Goldman Road Cream Ridge, NJ 08514	All Fittings	W. Flynn
01/02/98	UNION FOUNDRY CO./DIVISION OF McWANE P.O. Box 309 Anniston, AL 36202	All Series	W. Flynn
04/01/97	SOMEPE (SMP/BRAZIL)/ STAR PIPE PRODUCTS 4018 Westhollow Pkwy. Houston, TX 77082	All Fittings Includes Series 100 MJ x MJ Adaptor (bolt-through MJ restraint)	W. Flynn
07/01/96	INFACORP. 7555 Caney Fork Rd. Fairview, TX 37062	Foster MJ x MJ Adaptor (bolt-through MJ restraint)  (Use nuts recommended by manufacturer)	W. Flynn



**CITY OF AUSTIN  
STANDARD PRODUCTS LIST  
for  
COMPACT DUCTILE IRON FITTINGS**

**USING DEPARTMENT:** Water Utility    **ISSUED:** 10/01/87    **REVIEWED:** 04/01/13    **REVISED:** 04/01/13

**PREPARED BY:** William Flynn, P.E.    **CITY STOCK NUMBER:**

**DESCRIPTION:** Fittings, Compact Ductile Iron complying with AWWA C153 in 4", 6", 8", 12", 16", 20" and 24" sizes. All fittings shall have markings cast on the body as required by AWWA C153. Fittings shall be asphalt coated and cement-mortar lined with asphaltic seal coat complying with AWWA C104, or fusion-bonded epoxy coated and lined (inside and outside) complying with AWWA C116. Fusion-bonded epoxy must be red and comply with requirements of NSF 61. (See SPL WW-27 for Ductile Iron Fittings complying with AWWA C110.)

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
01/02/03	AMERICAN FLOW CONTROL P.O. Box 2727 Birmingham, AL 35202-2727	4" to 12"	R. Lamb
04/01/09	ASSURED FLOW SALES, INC. P.O. Box 49633 Sarasota, FL 34230	Gradelok	R. Lamb
04/01/10	SHANXI YUANSHENG (China) ACCUCAST 415 S. 21 <sup>st</sup> Ave. Waco, TX 76706	4" to 12"      Logo on Casting 	R. Lamb
04/01/13	GAOMI ZHONGYIDE (China) ACCUCAST	4" to 12" MJ x MJ Accu Adaptor (bolt-through MJ restraint)	R. Lamb
01/01/12	METALFIT (MEXICO) METALFIT 5583 Snowflake Way Parker, CO 80134	All Fittings Markings include Griffin or Metalfit	R. Lamb
10/01/12	BEIJING CHENGHONG WATER WORKS FOUNDRY (China) SERAMPORE (SIP) INDUSTRIES 2900 Patio Drive Houston, TX 77017	All Fittings	R. Lamb

**NOTE:**