

CITY OF AUSTIN STANDARD PRODUCTS LIST

for

DUCTILE IRON FITTINGS

USING DEPARTMENT: Austin Water PREPARED BY: Bill Flynn, P.E. ISSUED: 06/06/83

REVISED BY: Jeff Kyle, P.E. **REVISED:** 04/01/17

DESCRIPTION: Ductile Iron Fittings complying with AWWA C110. Fittings shall be asphalt coated and

cement-mortar lined with asphaltic seal coat complying with AWWA C104. Alternately, the fittings may be fusion-bonded epoxy lined and coated according to AWWA C116. (See SPL WW-27A for Joint Restraint Devices, see SPL WW-27B for Compact Ductile Iron Fittings and Fitting Weight Schedule complying with AWWA C153 and see SPL WW-27F for Restrained Joint Ductile Iron Pipe and Fittings.) Not for use in gravity

wastewater applications.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
07/01/98	AMERICAN CAST IRON PIPE CO. P.O. Box 2727 Birmingham, AL 35202	See notes	W. Flynn
07/01/98	U.S. PIPE & FOUNDRY CO. P.O. Box 10406 Birmingham, AL 35202	See notes	W. Flynn
07/01/98	TYLER UNION/DIVISION OF McWANE P.O. Box 309 Anniston, AL 36202	See notes	W. Flynn
04/01/04	C-1 FOUNDRY (CHINA), WFD, EC, SC, JX, XD, HD, EC FOUNDRIES (INDIA), HJ FOUNDRIES (KOREA) STAR PIPE PRODUCTS 4018 Westhollow Parkway Houston, TX 77082	See notes	R. Lamb
01/01/12	US PIPE/METALFIT (Mexico) METALFIT 5583 Snowflake Way Parker, CO 80134	Fittings Only (Flanged) See Notes	R. Lamb
07/01/13	SHANXI YUANSHENG China) ACCUCAST 415 S. 21 st Ave. Waco, TX 76706	Fittings Only (Flanged) See Notes	R. Lamb
10/01/13	CALCUTTA SPRINGS FOUNDRY (India), XYF FOUNDRY (China) SIGMA CORPORATION 500 Askins Houston, TX 77093	Flanged Only	R. Lamb
01/01/17	XINYUAN PIPE FITTINGS CO. (China) SERAMPORE (SIP) INDUSTRIES 2900 Patio Drive Houston, TX 77017	See notes	J. Kyle



NOTES:

- 1. Materials shall meet applicable specification requirements. Acceptable sizes are 4", 6", 8", 12", 16", 24", 30" and multiples of 6" in larger sizes. 14", 18" and 20" are acceptable for repair only.
- 2. Submittal shall include results of independent laboratory testing showing that seal coating on fittings meets test requirements of Section 5.2 of AWWA Standard C104, and is in compliance with Section 4.12 of that Standard.
- 3. For fittings larger than 24" diameter, manufacturer must provide one of the following with PROJECT submittal: a) evidence of current ISO registration, b) evidence of current Austin Water-approved quality control program, or c) evidence of current Austin Water-approved independent, third party firm that will test and inspect fittings produced for City of Austin, as per Standard Specification Item 510.

LATEST REVISIONS:

- 1. Add US Pipe & Foundry, US Pipe/Metalfit, and Accucast back to SPL (inadvertently removed with 01/01/17 SPL revision)
- 2. Change Tyler Pipe Foundry to Tyler Union/Division of McWane