



**CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
FLANGED DUCTILE IRON PIPE AWWA C115**

USING DEPARTMENT: Austin Water

PREPARED BY: Robert Lamb, P.E.

ISSUED: 04/01/03

REVISED BY: Jeff Kyle, P.E.

REVISED: 04/01/17

DESCRIPTION: Water Pipe, Ductile Iron, Flanged, meeting AWWA C115, cement-mortar lined with asphalt seal coat, and asphalt coated, except when specified otherwise. Machined flange faces shall have a rust-preventative coating. Not for use in gravity wastewater applications.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
04/01/03	FAST FABRICATORS, INC (formerly B & R Pipe Fabrication) 800 Burlington Road Saginaw, TX 76179	See notes below	R. Lamb
04/01/03	FOUNDRY SERVICES, INC. 4309 North 26 th Street Omaha, NE 68111	See notes below	R. Lamb
04/01/03	CUSTON FAB (San Antonio facility) 109 Fifth Street Orlando, FL 32824	See notes below	R. Lamb
04/01/03	METRO-TEX FABRICATORS, INC. 5107 Brookglen Drive Houston, TX 77017	See notes below	R. Lamb
04/01/03	U.S. PIPE & FOUNDRY CO. P.O. Box 10406 Birmingham, AL 35202	See notes below	R. Lamb
04/01/17	K&K Supply / Custom Pipe and Coupling 12641 FM 3083 Conroe, TX 77302	See notes below	J. Kyle

NOTES:

- Acceptable sizes are 4", 6", 8", 12", 16", 20", 24", 30", and multiples of 6" in larger sizes.
- D.I. Pipe by U.S. manufacturer.
- Certification required for testing of each joint to 300 psi minimum.
- For pipe larger than 24" diameter, manufacturer must provide one of the following with project submittal: a) evidence of current ISO registration, b) evidence of current Austin Water – approved quality control program, or c) name and qualifications of independent, third party firm that will test and inspect pipe produced for City of Austin, as per Standard Specification Item 510.

LATEST REVISIONS:

- Add K&K Supply / Custom Pipe & Coupling