CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
METER VAULTS

USING DEPARTMENT: Water Utility **ISSUED:** 10/01/97 **REVIEWED:** 01/01/15 **REVISED:** 01/01/15

PREPARED BY: Bill Flynn, P.E. **CITY STOCK NUMBER:**

DESCRIPTION: Meter Vault, rectangular, for 3", 4" or 6" compound meters and fire demand meters, with 8" removable reinforced concrete top having valve openings and aluminum access hatch(with stainless steel hardware) as listed in SPL WW-614. Vault, including removable top and access hatch, to be designed for H-20 loading. (Not to be installed in areas of high density traffic). Precast plant must be NPCA certified. Concrete used for pre-cast vaults shall conform to TxDOT Item 421, 2004 Edition.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
07/01/98	HANSON CONCRETE PRODUCTS 801 Airport Blvd. Austin, TX 78702	5' x 7' Compound Meter Vault designed by Douglas C. Hearn, Engr.	W. Flynn
10/01/02	HANSON CONCRETE PRODUCTS 501 East Baxter St. Sequin, TX 78155	Vaults as designed by Gary Munkelt & Assoc. on 8/12/02 5' x 7' Compound Meter Vault 8' x 12' Fire Demand Meter Vault 10' x 12' Fire Demand Meter Vault 10' x 15' Fire Demand Meter Vault	R. Lamb
07/01/04	HANSON CONCRETE PRODUCTS (WACO) P.O. Box 688 Hewitt, TX 76643	Vaults as designed by Steve Bontempo on 5/7/04 5' x 7' Compound Meter Vault 8' x 12' Fire Demand Meter Vault 10' x 12' Fire Demand Meter Vault 10' x 15' Fire Demand Meter Vault	R. Lamb

NOTE: 1. See shop drawings for approval of knockout and opening locations.

CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
METER VAULTS

USING DEPARTMENT: Water Utility **ISSUED:** 10/01/97 **REVIEWED:** 01/01/15 **REVISED:** 01/01/15

PREPARED BY: Bill Flynn, P.E. **CITY STOCK NUMBER:**

DESCRIPTION: Meter Vault, rectangular, for 3", 4" or 6" compound meters and fire demand meters, with 8" removable reinforced concrete top having valve openings and aluminum access hatch(with stainless steel hardware) as listed in SPL WW-614. Vault, including removable top and access hatch, to be designed for H-20 loading. (Not to be installed in areas of high density traffic). Precast plant must be NPCA certified. Concrete used for pre-cast vaults shall conform to TxDOT Item 421, 2004 Edition.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
04/01/07	CAPITAL CONCRETE PRODUCTS 5264 Hwy. 71 East Del Valle, TX 78617	Vaults as designed by Christopher Wickham on 7/11/06 5' x 7' Compound Meter Vault 8' x 12' Fire Demand Meter Vault 10' x 12' Fire Demand Meter Vault 10' x 15' Fire Demand Meter Vault	R. Lamb
04/01/10	CAPITAL PRECAST 800 Watson Lane East New Braunfels, TX 78130	Vaults as designed by Gary Munlet & Associates 5' x 7' Compound Meter Vault 8' x 12' Fire Demand Meter Vault 10' x 12' Fire Demand Meter Vault 10' x 15' Fire Demand Meter Vault	R. Lamb
07/01/11	PARK ENVIRONMENTAL EQUIPMENT 8491 U.S. Hwy 87 East San Antonio, TX 78263	Vaults designed by Gary Munlet & Associates on 9/7/10 5' x 8' Compound Meter Vault 8' x 12' Fire Demand Meter Vault 10' x 12' Fire Demand Meter Vault 10' x 15' Fire Demand Meter Vault	R. Lamb

NOTE: 1. See shop drawings for approval of knockout and opening locations.