



CITY OF AUSTIN
STANDARD PRODUCTS LIST
for

RESTRAINED JOINT PVC WATER PIPE (4-INCH TO 12-INCH DIAMETER)

USING DEPARTMENT: Water Utility **ISSUED:** 04/01/11 **REVIEWED:** 04/01/11 **REVISED:** 04/01/11

PREPARED BY: R. Lamb, P.E. **CITY STOCK NUMBER:**

DESCRIPTION: Pipe, polyvinyl chloride (PVC), 4" through 12" cast iron pipe size O.D. with elastomeric gasket joints and factory-installed internal joint restraint system for water service. Pipe must meet AWWA C900 DR14 Pressure Class 305. Joint restraint system must meet ASTM F 1674.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
04/01/11	JM EAGLE (formerly J-M Pipe & PW Eagle) 9 Peach Tree Hill Road Livingston, NJ 07039	Eagle Loc 900	R. Lamb
04/01/11	DIAMOND PLASTICS CORPORATION P.O. Box 2748 Lubbock, TX 79408-2748	Diamond Loc-21	R. Lamb

NOTE:

- Warning tape shall be placed on top of the pipe for the full length of restrained joint pipe. The warning tape shall be yellow and shall have black lettering at least 2 inches high that states "Restrained Joint / Junta de Restriccion" at intervals not exceeding 24 inches. The warning tape shall be polypropylene having a minimum thickness of 2 mils, a minimum width of 3 inches, and adhesive backing on the side opposite the lettering.
- Material must comply with requirement of description above and be rated above design pressure. Acceptable sizes are 4", 6", 8" and 12".
- AWWA C900 water pipe shall not be used in easements on private property and shall not be used for wastewater force mains or to convey anything but potable water.

[Inspector—show location of restrained pipe and fittings on intersection drawings. Also show on record drawings along with manufacturer's name.]