



CITY OF AUSTIN
STANDARD PRODUCTS LIST
for

ORGANIC LINING FOR WASTEWATER MANHOLES

USING DEPARTMENT: Water Utility **ISSUED:** 05/10/84 **REVIEWED:** 01/01/14 **REVISED:** 01/01/14

PREPARED BY: Bill Flynn, P.E./David Rinn **CITY STOCK NUMBER:**

DESCRIPTION: Lining, Corrosion Resistant, spray or brush applied. Material shall be urethane, polyurethane or epoxy. Permitted uses as noted in Product Identification/Comment below. Substrate and surface preparation, application conditions, application equipment, material preparation, and curing shall be in strict accordance with manufacturer's written recommendations (product technical data sheet) unless written documentation from manufacturer requesting variance has been approved by the Austin Water Utility.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
01/02/97	RAVEN CHEMICALS 1024 North Lansing Tulsa, OK 74106	400 Series High Build Epoxy Liner, 80 mils minimum thickness Permitted Uses: See notes 3, 4, 5, 6, and 7 Applicators: Lewis Concrete Restoration, Eric Lewis National Power Rodding Ace Pipe Cleaning, Inc. Approval Expires August 1, 2015	R. Lamb
01/02/97	SPRAYROQ. INC. 4707 Alton Court P.O. Box 101717 Birmingham, AL 35210	Spraywall Process, 80 Mils minimum thickness Permitted Uses: See notes 3, 4, 5, 6, and 7 Applicator: Fuquay, Inc., John Fuquay Approval Expires August 1, 2015	R. Lamb
07/01/97	SEALING SYSTEMS, INC. 23230 West Thomess Blvd. Loretto, MN 55357	Flex-Seal with Primer, 80 mils minimum thickness Permitted Uses: Only in chimney area over grade rings Approved Applicator not required Approval Expires August 1, 2015	R. Lamb
10/01/13	QUADEX 4801 Crystal Hill Rd. North Little Rock, AR 72118	Structure Guard, 80 mils minimum thickness Permitted Uses: See notes 3, 4, 5, 6, and 7 Applicator: Lewis Concrete Restoration, Eric Lewis Approval Expires August 1, 2015	R. Lamb

NOTE:

- Lining product used for repair shall be the same as that used in original application. Use of a different product, even if it is compatible with the original lining, requires written approval of the Austin Water Utility.
- The Contractor is responsible for coating application as required for the interior surface of sectional concrete manholes. If shop-coated sections are used, contractor shall apply touch-up as required and shall completely coat the interior of all grade-adjustment rings and invert areas using the same product as applied in the shop.
- Product may be applied to new manholes before wastewater lines are put into use or before hydrostatic testing of wastewater line or manhole, when allowed.
- Product may be applied to new manholes after wastewater lines have been put into use or after hydrostatic testing of wastewater line or manhole, when allowed.
- Product may be applied to existing manholes for rehabilitation. Minimum thickness will increase depending on manhole condition.
- Product may be applied to new lift station wet well before operation.
- Product may not to be used, regardless of any other permitted uses, if any part of the manhole or lift station wet well extends below existing groundwater level unless a water-proofing system, as specified on the drawings, is applied at the same time to the exterior surface of the manhole or wet well.