



**CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
SEAMLESS COPPER TUBING**

USING DEPARTMENT: Water Utility **ISSUED:** 10/01/97 **REVIEWED:** 04/01/09 **REVISED:** 04/01/09

PREPARED BY: Bill Flynn **CITY STOCK NUMBER:**

DESCRIPTION: Tubing, Copper, ½" through 2", shall be annealed seamless Type K water tube meeting ASTM B 88 bearing NSF Standard 61 approval.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
09/03/97	MUELLER COPPER TUBE CO. P.O. Box 849 Fulton, MS 38843	As described above (see Notes)	K. Flowers
01/26/98	CERRO COPPER PRODUCTS CO. P.O. Box 66880 St. Louis, MO 63166-6800	As described above Cerro Alloy C122 (see Notes)	K. Flowers
03/01/02	CAMBRIDGE-LEE INDUSTRIES 4500 Hugh Howell Road Suite 770 Tucker, GA 30084	As described above (see Notes)	K. Flowers
05/01/02	HOWELL METAL COMPANY P.O. Box 218 574 Depot Road New Market, VA 22844	As described above (see Notes)	K. Flowers
07/01/05	KOBWEILAND COPPER PRODUCTS, INC. P.O. Box 160 Pine Hall, NC 27042	As described above (see Notes)	R. Lamb

- NOTE:**
1. Tubing shall be wrapped with black polyethylene sheeting for potable water and purple polyethylene sheeting for reclaimed water.
 2. Polyethylene sheeting shall extend into the meter box.