



**CITY OF AUSTIN  
STANDARD PRODUCTS LIST**  
for  
**POLYETHYLENE TUBING FOR POTABLE WATER SERVICES**

**USING DEPARTMENT:** Water Utility    **ISSUED:** 02/03/78    **REVIEWED:** 10/01/14    **REVISED:** 10/01/14

**PREPARED BY:** Bill Flynn, P.E.    **CITY STOCK NUMBER:**

**DESCRIPTION:** Tubing, polyethylene, meeting AWWA C901 and NSF 61 certified, CTS-OD ¾" thru 2", made of PE 4710, minimum Pressure Class 250 psi (SDR-9), solid blue exterior with clear center and black heat-indented printline or solid blue wall with white heat-indented printline. Only compression fittings recommended by the manufacturer and compatible with stainless steel insert stiffeners may be used.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
01/01/10	ENDOT INDUSTRIES, INC. 60 Green Pond Road Rockaway, NJ 07866	EndoPure	R. Lamb
10/01/14	SILVER-LINE PLASTICS CORP. 900 Riverside Drive Asheville, NC 28804	Silver-Line Ultra-Pure	R. Lamb

**NOTE:**

1. Printline shall include all markings required by AWWA C901: nominal tubing size and diameter base, SDR, manufacturer's name or trademark, material designation code, pressure class, AWWA standard number, seal of mark of the testing agency that certifies the tubing material for potable water service, date of manufacture that is recognizable as a date, and manufacturer's production code that includes resin source, manufacturing location, and extrusion line.
2. Tracer tape meeting SPL WW-597 to be installed 12 inches above top of tubing.