



CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
BRASS GOODS

USING DEPARTMENT: Water Utility **ISSUED:** 02/16/82 **REVIEWED:** 01/01/16 **REVISED:** 01/01/16

PREPARED BY: David Rinn **CITY STOCK NUMBER:**

DESCRIPTION: Brass goods - including but not limited to ball type corporation valves, ball curb stops, angle ball service valves, angle ball meter valves, couplings, coupling bends, water meter couplings, corporation stop couplings, branch connections and water meter relocater yokes. Service tubing connections shall be made with approved grip type compression connections. When used with polyethylene tubing, tubular stainless steel insert stiffeners shall be used. Pressure rating of at least 200 psi. Shall conform to AWWA C800, where applicable. Effective January 1, 2013, all brass goods purchased for City forces shall be "lead free" and marked by stamping, etching, or casting "NL" in the main body or by other methods acceptable to City. Effective January 4, 2014, all brass goods shall be "lead free."

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
04/01/98	JAMES JONES COMPANY 4127 Temple City Blvd. El Monte, CA 91731	Corporation Stop Ball Valve 1½" and 2" Model J-1935 SG CTS (Super Grip w/standard copper flare threads) Coupling Y-Branch 60 degree CTS 1½" x 1" x 1" Model J-2630 J1966W Angle meter stops by James Jones are not acceptable.	R. Lamb
04/01/98	MUELLER COMPANY 500 West Eldorado Decatur, IL 62525	Corporation Stop Ball Valve 1½" and 2" Model B25028-36N (MIP x SG CTS threads) Mueller 110 Compression connections required for tubing. The following Mueller items are not acceptable: - Insta-Tite Connections - 1 angle stop with meter saddle	K. Flowers
04/01/98	FORD METER BOX COMPANY P.O. Box 443 Wabash, IN 46992-0443	Grip Joint compression connection required for service tubing.	K. Flowers
10/01/98	CAMBRIDGE BRASS (Formerly Hays Brass) 140 Orion Place Cambridge, Ontario N1R 5V1	Corporation Stop Ball Valve Model 301-A3H3 Model 301-A4H4 1½" and 2" not acceptable	R. Lamb

NOTE:



CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
BRASS GOODS

USING DEPARTMENT: Water Utility **ISSUED:** 02/16/82 **REVIEWED:** 01/01/16 **REVISED:** 01/01/16

PREPARED BY: David Rinn **CITY STOCK NUMBER:**

DESCRIPTION: Brass goods - including but not limited to ball type corporation valves, ball curb stops, angle ball service valves, angle ball meter valves, couplings, coupling bends, water meter couplings, corporation stop couplings, branch connections and water meter relocater yokes. Service tubing connections shall be made with approved grip type compression connections. When used with polyethylene tubing, tubular stainless steel insert stiffeners shall be used. Pressure rating of at least 200 psi. Shall conform to AWWA C800, where applicable. Effective January 1, 2013, all brass goods purchased for City forces shall be "lead free" and the marked by stamping, etching, or casting "NL" in the main body. Effective January 4, 2014, all brass goods shall be "lead free."

04/01/98	A.Y. MC DONALD COMPANY Box 508 Dubuque, Iowa 52001	<p>Angle Valves 74602BCSG 1½" & 2" 74602BCSQ 1½" & 2"</p> <p>Corporation Stops 74704BGFT 1½" & 2" 74704BG ¾" & 1" 74704BQ ¾" & 1" 74704BTFT 1½" & 2" 74704BT ¾" & 1"</p> <p>Y-Branches 708Y2MG 1½" x 1" 708Y2MQ 1½" x 1" 708Y2MT 1½" x 1"</p>	R. Lamb
----------	--	---	---------

NOTE: