



CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
RESILIENT-SEATED GATE VALVES, AWWA C515

USING DEPARTMENT: Water Utility **ISSUED:** 01/03/00 **REVIEWED:** 10/01/14 **REVISED:** 10/01/14

PREPARED BY: Jim Edwards **CITY STOCK NUMBER:**

DESCRIPTION: Resilient-Seated Gate Valves, Reduced -Wall, AWWA C515 (2" and larger) non-rising stem type having ends with gaskets, glands, bolts, etc. as specified. Copper alloy parts (bronze or brass) shall contain not over 16 percent zinc. Copper alloy UNS No. shall be shown on permanent external marking in addition to markings required by AWWA C515. Valve stems shall turn clockwise to close. Interior and exterior coatings of ferrous surfaces as required by AWWA C515 shall be fusion bonded epoxy.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
01/03/00	AMERICAN FLOW CONTROL P.O. Box 2727 Birmingham, AL 35202-2727	Series 2500-1 (3" - 12") Series 2500 (14" and larger)	R. Lamb
01/03/00	CLOW VALVE CO. 902 South 2 nd Street Oskaloosa, IA 52577	Model No. 2638 (4" and larger)	R. Lamb
01/03/00	MUELLER CO. 500 West Eldorado Street Decatur, IL 62525-1808	A-2361 (4" and larger)	R. Lamb
10/01/05	AMERICAN AVK CO. 5286 East Home Avenue Fresno, CA 93727	Series 55 (18" and larger)	R. Lamb
07/01/08	EJ (formerly East Jordan Iron Works) 301 Spring Street East Jordan, MI 49727	FlowMaster (4" and larger)	R. Lamb

NOTE:

- Contractor's/manufacture's **PROJECT** submittal for valves larger than 24" diameter, when approved for use, shall include catalogue drawings and assembly drawings (shop drawings) specific to valves required for the project.
- All valves 24" and larger shall be geared.
- Bypasses are not required on these valves regardless of size.