



[STEERS Home](#) |
 [Help](#) |
 [Contact Us](#) |
 [Logout](#)
[Select ID](#) |
 [Select Outfall](#) |
 [Work Area](#)



14:56

View Selected Report

EPA ID: TX0101532, TPDES: 13318001

EPA ID: TX0101532

TPDES: 13318001

Permittee Name: AUSTIN, CITY OF

Maj/Min: Major

Facility Name: HARRIS BRANCH WWTP

Facility Location: AUSTIN

Outfall: 001A

DOMESTIC FACILITY - 001

Outfall Type: EFFLUENT

Monitoring Period: 05/01/2009-05/31/2009

Limit Type: INTERIM

Message from TCEQ: INTERIM I PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.80 MGD FACILITIES. 13318-001 _____*

Parameter: OXYGEN, DISSOLVED (DO): EFFLUENT GROSS VALUE - 00300 - 1
Status: VALID

	Sample Measurement	Permit Requirement	
Concentration Minimum	7.6	5.0 MG/L	MONTHLY MINIMUM
Frequency of Analysis	WEEKLY	WEEKLY	
Sample Type	GRAB	GRAB	
Number of Exceedances	00		

Parameter: PH: EFFLUENT GROSS VALUE - 00400 - 1
Status: VALID

Comment: Actual frequency of analysis: weekly.

	Sample Measurement	Permit Requirement	
Concentration Minimum	6.5	6.0 SU	MINIMUM
Concentration Maximum	6.9	9.0 SU	MAXIMUM
Frequency of Analysis	WEEKLY	ONCE/MONTH	
Sample Type	GRAB	GRAB	
Number of Exceedances	00		

Parameter: SOLIDS, TOTAL SUSPENDED: EFFLUENT GROSS VALUE - 00530 - 1
Status: VALID

	Sample Measurement	Permit Requirement	
Quantity Average	3.4	17 LBS/DY	DAILY AVERAGE
Concentration Average	2	5 MG/L	DAILY AVERAGE
Concentration Maximum	2	30 MG/L	SINGLE GRAB
Frequency of Analysis	WEEKLY	WEEKLY	
Sample Type	GRAB	GRAB	
Number of Exceedances	00		

Parameter: NITROGEN, AMMONIA TOTAL (AS N): EFFLUENT GROSS VALUE - 00610 - 1
Status: VALID

	Sample Measurement	Permit Requirement	
Quantity Average	0.2	6.7 LBS/DY	DAILY AVERAGE
Concentration Average	0.08	2 MG/L	DAILY AVERAGE
Concentration Maximum	0.1	15 MG/L	SINGLE GRAB
Frequency of Analysis	WEEKLY	WEEKLY	
Sample Type	GRAB	GRAB	
Number of Exceedances	00		

Parameter: PHOSPHORUS, TOTAL (AS P): EFFLUENT GROSS VALUE - 00665 - 1
Status: VALID

	Sample Measurement	Permit Requirement	
Quantity Average	1.5	3.3 LBS/DY	DAILY AVERAGE
Concentration Average	0.8	1 MG/L	DAILY AVERAGE
Concentration Maximum	1.0	6 MG/L	SINGLE GRAB
Frequency of Analysis	WEEKLY	WEEKLY	
Sample Type	GRAB	GRAB	
Number of Exceedances	00		

Parameter: FLOW, IN CONDUIT OR THRU TREATMENT PLANT: EFFLUENT GROSS VALUE - 50050 - 1
Status: VALID
Comment: Flow readings recorded daily.

	Sample Measurement	Permit Requirement	
Quantity Average	0.22	0.40 MGD	DAILY AVERAGE
Quantity Maximum	0.30	REPORT MGD	DAILY MAXIMUM
Frequency of Analysis	DAILY	5 TMS/WEEK	
Sample Type	INSTAN	INSTAN	
Number of Exceedances	00		

Parameter: CHLORINE, TOTAL RESIDUAL: EFFLUENT GROSS VALUE - 50060 - 1
Status: VALID
Comment: Actual frequency of analysis: Daily.

	Sample Measurement	Permit Requirement	
Concentration Minimum	1.0	1.0 MG/L	MONTHLY MINIMUM
Concentration Maximum	3.0	4.0 MG/L	MONTHLY MAXIMUM
Frequency of Analysis	DAILY	5 TMS/WEEK	
Sample Type	GRAB	GRAB	
Number of Exceedances	00		

Parameter: BOD, CARBONACEOUS 05 DAY, 20C: EFFLUENT GROSS VALUE - 80082 - 1
Status: VALID

	Sample Measurement	Permit Requirement	
Quantity Average	< 3.9	17 LBS/DY	DAILY AVERAGE
Concentration Average	< 2	5 MG/L	DAILY AVERAGE
Concentration Maximum	< 2	30 MG/L	SINGLE GRAB
Frequency of Analysis	WEEKLY	WEEKLY	
Sample Type	GRAB	GRAB	
Number of Exceedances	00		

[View Work Area](#)