

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

NAME **SOUTH AUSTIN REGIONAL**
 ADDRESS **625 E 10TH STREET**
AUSTIN, TX 78701
 FACILITY **CITY OF AUSTIN (SOUTH)**
 LOCATION **DEL VALLE, TX 78617**
 ATTN: **GREG MESZAROS, DIRECTOR**

(2-16)			(17-19)		
TX0071889			001 A		
PERMIT NUMBER			DISCHARGE NUMBER		
MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 09	03	01	TO 09	03	31
<small>(20-21)</small>	<small>(22-23)</small>	<small>(24-25)</small>	<small>(26-27)</small>	<small>(28-29)</small>	<small>(30-31)</small>

MAJOR

F - FINAL DOMESTIC FACILITY - 001

NO DISCHARGE

NOTE: Read instructions before completing this form.

PARAMETER <small>(32-37)</small>		QUANTITY OR LOADING <small>(3 Card Only (46-53) (54-61))</small>			QUALITY OR CONCENTRATION <small>(4 Card Only (38-45) (46-53) (54-61))</small>			NO. EX <small>(62-63)</small>	FREQUENCY OF ANALYSIS <small>(64-68)</small>	SAMPLE TYPE <small>(69-70)</small>	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
OXYGEN, DISSOLVED (DO) 00300 EFFLUENT GROSS VALUE 1 0 0	SAMPLE MEASUREMENT	*****	*****	*****	7.8	*****	*****	(19)	0	DAILY	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	6.0 MO MIN	*****	*****	MG/L		DAILY	GRAB
PH 00400 EFFLUENT GROSS VALUE 1 0 0	SAMPLE MEASUREMENT	*****	*****	*****	6.8	*****	7.1	(12)	0	DAILY	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		DAILY	GRAB
SOLIDS, TOTAL SUSPENDED 00530 EFFLUENT GROSS VALUE 1 0 0	SAMPLE MEASUREMENT	781	*****	(26)	*****	3	5	(19)	0	DAILY	COMP OS
	PERMIT REQUIREMENT	9383 DAILY AVG	*****	LBS/DY	*****	15 DAILY AVG	40 DAILY MAX	MG/L		DAILY	COMP OS
NITROGEN, AMMONIA TOTAL (AS N) 00610 EFFLUENT GROSS VALUE 1 0 0	SAMPLE MEASUREMENT	61	*****	(26)	*****	0.2	1.0	(19)	0	DAILY	COMP OS
	PERMIT REQUIREMENT	1251 DAILY AVG	*****	LBS/DY	*****	2 DAILY AVG	10 DAILY MAX	MG/L		DAILY	COMP 24
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 SEE COMMENTS BELOW P 0 0	SAMPLE MEASUREMENT	*****	37,000	(78)	*****	*	*	*****	0	CONTINUOUS	TOTALZ
	PERMIT REQUIREMENT	*****	150,000 2HR PEAK	GPM	*****	*	*	*****	*****	CONTINUOUS	TOTALZ
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 ANNUAL AVERAGE Y 0 0	SAMPLE MEASUREMENT	33.6	*****	(03)	*****	*	*	*****	0	CONTINUOUS	TOTALZ
	PERMIT REQUIREMENT	75 ANNL AVG	*****	MGD	*****	*	*	*****	*****	CONTINUOUS	TOTALZ
FLOW IN CONDUIT OR THRU TREATMENT PLANT 50050 EFFLUENT GROSS VALUE 1 0 0	SAMPLE MEASUREMENT	34.6	41.7	(03)	*****	*****	*****	*****	0	CONTINUOUS	TOTALZ
	PERMIT REQUIREMENT	REPORT DAILY AVG	REPORT DAILY MAX	MGD	*****	*****	*****	*****	*****	CONTINUOUS	TOTALZ

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.	TELEPHONE		DATE		
Greg Meszaros, Director Austin Water Utility		(512) 972-0101	09	04	10	
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

INTERIM LIMITS IN EFFECT UNTIL COMPLETION OF 75 MGD FACILITY. P = 2-HOUR PEAK FLOW.

75 MGD FACILITY COMPLETED ON JUNE 22ND, THEREFORE, FINAL PHASE OF EXISTING PERMIT BECAME EFFECTIVE JUNE 22, 2006.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

NAME **SOUTH AUSTIN REGIONAL**
 ADDRESS **625 E 10TH STREET**
AUSTIN, TX 78701
 FACILITY **CITY OF AUSTIN (SOUTH)**
 LOCATION **DEL VALLE, TX 78617**
 ATTN: **GREG MESZAROS, DIRECTOR**

(2-16)			(17-19)		
TX0071889			001 A		
PERMIT NUMBER			DISCHARGE NUMBER		
MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 09	03	01	TO 09	03	31
<small>(20-21)</small>	<small>(22-23)</small>	<small>(24-25)</small>	<small>(26-27)</small>	<small>(28-29)</small>	<small>(30-31)</small>

MAJOR

F- FINAL DOMESTIC FACILITY - 001

NO DISCHARGE

NOTE: Read instructions before completing this form.

PARAMETER <small>(32-37)</small>		QUANTITY OR LOADING <small>(3 Card Only (46-53) (54-61))</small>			QUALITY OR CONCENTRATION <small>(4 Card Only (38-45) (46-53) (54-61))</small>			NO. EX <small>(62-63)</small>	FREQUENCY OF ANALYSIS <small>(64-68)</small>	SAMPLE TYPE <small>(69-70)</small>	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
CHLORINE, TOTAL RESIDUAL 50060 A 0 0 DISINFECT, PRCS CMPLT	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0.00	(19)	0	DAILY	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	0.099 INST MAX	MG/L		DAILY	GRAB
CHLORINE, TOTAL RESIDUAL 50060 B 0 0 PRIOR TO DISINFECT	SAMPLE MEASUREMENT	*****	*****	*****	1.0	*****	*****	(19)	0	DAILY	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	1.0 MO MIN	*****	*****	MG/L		DAILY	GRAB
BOD, CARBONACEOUS 05 DAY, 20C 80082 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	<593	*****	(26)	*****	<2	2	(19)	0	DAILY	COMP OS
	PERMIT REQUIREMENT	6255 DAILY AVG	*****	LBS/DY	*****	10 DAILY AVG	25 DAILY MAX	MG/L		DAILY	COMP OS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.					TELEPHONE		DATE			
Greg Meszaros, Director Austin Water Utility						(512) 972-0101		09	04	10	
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					AREA CODE	NUMBER	YEAR	MO	DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

INTERIM LIMITS IN EFFECT UNTIL COMPLETION OF 75 MGD FACILITY. P = 2-HOUR PEAK FLOW. 75 MGD FACILITY COMPLETED ON JUNE 22ND, THEREFORE, FINAL PHASE OF EXISTING PERMIT BECAME EFFECTIVE JUNE 22, 2006.

cBOD LE (lab error) on 3/15,16, 21/09 due to STD not within QC limits, calculated result - <2 mg/L on those days.