



[STEERS Home](#) |
 [Help](#) |
 [Contact Us](#) |
 [Logout](#)
[Select ID](#) |
 [Select Outfall](#) |
 [Work Area](#)



14:56

View Selected Report

EPA ID: TX0067466, TPDES: 14459001

EPA ID: TX0067466

TPDES: 14459001

Permittee Name: AUSTIN, CITY OF

Maj/Min: Minor

Facility Name: THOROUGHbred FARMS WWTP

Facility Location: AUSTIN

Outfall: 001A DOMESTIC FACILITY - 001

Outfall Type: EFFLUENT

Monitoring Period: 05/01/2009-05/31/2009

Limit Type: FINAL

Message from TCEQ: 14459-001

Parameter: OXYGEN, DISSOLVED (DO): EFFLUENT GROSS VALUE - 00300 - 1
Status: VALID

	Sample Measurement	Permit Requirement	
Concentration Minimum	3.8	2.0 MG/L	MONTHLY MINIMUM
Frequency of Analysis	WEEKLY	WEEKLY	
Sample Type	GRAB	GRAB	
Number of Exceedances	00		

Parameter: BOD, 5-DAY (20 DEG. C): EFFLUENT GROSS VALUE - 00310 - 1
Status: VALID

Comment: Actual frequency of analysis: 5 times/month.

	Sample Measurement	Permit Requirement	
Quantity Average	< 0.4	11 LBS/DY	DAILY AVERAGE
Concentration Average	< 2	20 MG/L	DAILY AVERAGE
Concentration Maximum	3	65 MG/L	SINGLE GRAB
Frequency of Analysis	5 TMS/MONTH	WEEKLY	
Sample Type	GRAB	GRAB	
Number of Exceedances	00		

Parameter: PH: EFFLUENT GROSS VALUE - 00400 - 1
Status: VALID

Comment: Frequency of analysis: 21 times/month.

	Sample Measurement	Permit Requirement	
Concentration Minimum	7.1	6.0 SU	MINIMUM
Concentration Maximum	7.9	9.0 SU	MAXIMUM
Frequency of Analysis	21 PER MONTH	ONCE/MONTH	
Sample Type	GRAB	GRAB	
Number of Exceedances	00		

Parameter: SOLIDS, TOTAL SUSPENDED: EFFLUENT GROSS VALUE - 00530 - 1
Status: VALID

Comment: Actual frequency of analysis: 5 times/month.

	Sample Measurement	Permit Requirement	
Quantity Average	0.4	11 LBS/DY	DAILY AVERAGE
Concentration Average	2	20 MG/L	DAILY AVERAGE
Concentration Maximum	3	65 MG/L	SINGLE GRAB
Frequency of Analysis	5 TMS/MONTH	WEEKLY	
Sample Type	GRAB	GRAB	

Number of Exceedances 00

Parameter: FLOW, IN CONDUIT OR THRU TREATMENT PLANT: EFFLUENT GROSS VALUE - 50050 - 1

Status: VALID

Comment: Flow calculated daily.

	Sample Measurement	Permit Requirement	
Quantity Average	0.020	0.065 MGD	DAILY AVERAGE
Quantity Maximum	0.026	REPORT MGD	DAILY MAXIMUM
Frequency of Analysis	5 TMS/WEEK	5 TMS/WEEK	
Sample Type	INSTAN	INSTAN	
Number of Exceedances	00		

Parameter: CHLORINE, TOTAL RESIDUAL: EFFLUENT GROSS VALUE - 50060 - 1

Status: VALID

	Sample Measurement	Permit Requirement	
Concentration Minimum	1.0	1.0 MG/L	MONTHLY MINIMUM
Concentration Maximum	3.6	4.0 MG/L	MONTHLY MAXIMUM
Frequency of Analysis	5 TMS/WEEK	5 TMS/WEEK	
Sample Type	GRAB	GRAB	
Number of Exceedances	00		

[View Work Area](#)