



[STEERS Home](#) |
 [Help](#) |
 [Contact Us](#) |
 [Logout](#)
[Select ID](#) |
 [Select Outfall](#) |
 [Work Area](#)



14:56

View Selected Report

EPA ID: TX0124800, TPDES: 10543013

EPA ID: TX0124800

TPDES: 10543013

Permittee Name: AUSTIN, CITY OF

Maj/Min: Minor

Facility Name: WILD HORSE RANCH WWTP

Facility Location: AUSTIN

Outfall: 001A

DOMESTIC FACILITY - 001

Outfall Type: EFFLUENT

Monitoring Period: 05/01/2009-05/31/2009

Limit Type: INTERIM

Message from TCEQ: INTERIM PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.99 MGD FACILITIES. WQ0010543-013 _____ WQ0010543-013

Parameter: OXYGEN, DISSOLVED (DO): EFFLUENT GROSS VALUE - 00300 - 1

Status: VALID

Comment: Actual frequency of analysis: 19 times/month.

	Sample Measurement	Permit Requirement	
Concentration Minimum	7.5	5.0 MG/L	MONTHLY MINIMUM
Frequency of Analysis	19 PER MONTH	WEEKLY	
Sample Type	GRAB	GRAB	
Number of Exceedances	00		

Parameter: PH: EFFLUENT GROSS VALUE - 00400 - 1

Status: VALID

Comment: Actual frequency of analysis: 19 times/month.

	Sample Measurement	Permit Requirement	
Concentration Minimum	6.8	6.0 SU	MINIMUM
Concentration Maximum	7.2	9.0 SU	MAXIMUM
Frequency of Analysis	19 PER MONTH	TWICE/MONTH	
Sample Type	GRAB	GRAB	
Number of Exceedances	00		

Parameter: SOLIDS, TOTAL SUSPENDED: EFFLUENT GROSS VALUE - 00530 - 1

Status: VALID

	Sample Measurement	Permit Requirement	
Quantity Average	1.1	31 LBS/DY	DAILY AVERAGE
Concentration Average	0.8	5 MG/L	DAILY AVERAGE
Concentration Maximum	0.9	20 MG/L	DAILY MAXIMUM
Frequency of Analysis	WEEKLY	WEEKLY	
Sample Type	COMPOS	COMPOS	
Number of Exceedances	00		

Parameter: NITROGEN, AMMONIA TOTAL (AS N): EFFLUENT GROSS VALUE - 00610 - 1

Status: VALID

	Sample Measurement	Permit Requirement	
Quantity Average	< 0.03	13 LBS/DY	DAILY AVERAGE
Concentration Average	< 0.02	2 MG/L	DAILY AVERAGE
Concentration Maximum	0.03	7 MG/L	DAILY MAXIMUM
Frequency of Analysis	WEEKLY	WEEKLY	
Sample Type	COMPOS	COMPOS	

Number of Exceedances 00

Parameter: PHOSPHORUS, TOTAL (AS P): EFFLUENT GROSS VALUE - 00665 - 1
 Status: VALID

	Sample Measurement	Permit Requirement	
Quantity Average	0.05	6.3 LBS/DY	DAILY AVERAGE
Concentration Average	0.03	1 MG/L	DAILY AVERAGE
Concentration Maximum	0.05	4 MG/L	DAILY MAXIMUM
Frequency of Analysis	WEEKLY	WEEKLY	
Sample Type	COMPOS	COMPOS	
Number of Exceedances	00		

Parameter: FLOW, IN CONDUIT OR THRU TREATMENT PLANT: EFFLUENT GROSS VALUE - 50050 - 1
 Status: VALID

	Sample Measurement	Permit Requirement	
Quantity Average	0.18	0.75 MGD	DAILY AVERAGE
Quantity Maximum	0.25	REPORT MGD	DAILY MAXIMUM
Frequency of Analysis	CONTINUOUS	CONTINUOUS	
Sample Type	TOTALZ	TOTALZ	
Number of Exceedances	00		

Parameter: COLIFORM, FECAL GENERAL: EFFLUENT GROSS VALUE - 74055 - 1
 Status: VALID

	Sample Measurement	Permit Requirement	
Concentration Average	< 1	200 CFU/100ML	DAILY AVERAGE
Concentration Maximum	< 1 ✓	400 CFU/100ML	7 DAY AVERAGE
Frequency of Analysis	DAILY	DAILY	
Sample Type	GRAB	GRAB	
Number of Exceedances	00		

Parameter: BOD, CARBONACEOUS 05 DAY, 20C: EFFLUENT GROSS VALUE - 80082 - 1
 Status: VALID

	Sample Measurement	Permit Requirement	
Quantity Average	< 2.8	31 LBS/DY	DAILY AVERAGE
Concentration Average	< 2	5 MG/L	DAILY AVERAGE
Concentration Maximum	< 2	20 MG/L	DAILY MAXIMUM
Frequency of Analysis	WEEKLY	WEEKLY	
Sample Type	COMPOS	COMPOS	
Number of Exceedances	00		

[View Work Area](#)