TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865

40B SYS	WQ0010543-011 PERMIT NUMBER	1 SET	0 9 YEAR	0 7 MO.	15650 EID

THIS REPORT TO BE USED FOR RECLAIMED WATER TYPE I "800"

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER		EFFLUENT CONDITION VALUE	UNITS	NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
316164024 FEC. COLI	REPORTED	<1	#/100 ML	0	11		03	
DLY AVG	PERMITTED	20.000			11	2/WEEK	03	GRABPKLOAD
316164030 FEC. COLI	REPORTED	<4	#/100 ML	0	11		03	
IND GRAB	PERMITTED	75.000			11	2/WEEK	03	GRABPKLOAD
500507124 FLOW	REPORTED	0.48	MGD	0	02		11	
DLY AVG	PERMITTED				02	CONT	11	CONT
800821024 BOD CARB	REPORTED	<2	MG/L	0	11		03	
DLY AVG	PERMITTED	5.000			11	2/WEEK	03	GRABPKLOAD
820796624 TURBIDITY	REPORTED	0.77	NTU	0	11		03	
30DAYAVG	PERMITTED	3.000			11	2/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR	REPORTED	WW0018247	NUMBER	0	01		01	
CERTIFICATE	PERMITTED				01	NA	01	NA
EXPIRATION OF OPERATOR	REPORTED	09/11/12	DATE	0	01		01	
CERTIFICATE	PERMITTED				01	NA	01	NA
CLASS OF OPERATOR	REPORTED	A	LETTER	0	01		01	
CERTIFICATE	PERMITTED				01	NA	01	NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

Data represents reclaimed water flow from Walnut Creek WWTP TPDES Permit # 10543-011 EPA ID TX0046981. Walnut Creek WWTP transferred reclaimed water for 31 days.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Mike Welch		0 9 (YEAR) 0 8 (MO.) 0 7 (DAY)
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	
5 1 2 (AREA CODE) 9 7 2 0 1 0 1 (NUMBER)	Greg Meszaros, Director		0 9 (YEAR) 0 8 (MO.) 0 7 (DAY)
	EXECUTIVE OFFICER	EXECUTIVE OFFICER	

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865

40B	WQ0010543-012	1	0 9	0 7	15651
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR RECLAIMED WATER TYPE II "900"

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER		EFFLUENT CONDITION VALUE	UNITS	NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
000085342 TRANSFER	REPORTED	31	DAY	0	01		01	
DAYS MON	PERMITTED				01	NA	01	NA
316164024 FEC. COLI	REPORTED	<1	#/100 ML	0	11		03	
DLY AVG	PERMITTED	200.000			11	2/WEEK	03	GRABPKLOAD
316164030 FEC. COLI	REPORTED	<2	#/100 ML	0	11		03	
IND GRAB	PERMITTED	800.000			11	2/WEEK	03	GRABPKLOAD
500507124 FLOW	REPORTED	5.05	MGD	0	02		11	
DLY AVG	PERMITTED				02	CONT	11	CONT
800821024 BOD CARB	REPORTED	<2	MG/L	0	11		03	
DLY AVG	PERMITTED	15.000			11	2/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR	REPORTED	WW0011708	NUMBER	0	01		01	
CERTIFICATE	PERMITTED				01	NA	01	NA
EXPIRATION OF OPERATOR	REPORTED	12/05/12	DATE	0	01		01	
CERTIFICATE	PERMITTED				01	NA	01	NA
CLASS OF OPERATOR	REPORTED	B	LETTER	0	01		01	
CERTIFICATE	PERMITTED				01	NA	01	NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

Data represents reclaimed water flow from South Austin Regional WWTP TPDES Permit # 10543-012, EPA ID TX0071889

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Randall Swenson	Randall Swenson	0 9 / 0 8 / 0 7
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR / MO. / DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director		0 9 / 0 8 / 0 7
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR / MO. / DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865

40B	WQ0010543-011	1	09	07	15652
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR **COMBINED TYPE I AND II RECLAIMED WATER**

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER		EFFLUENT CONDITION VALUE	UNITS	NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
500507124 FLOW	REPORTED	5.53	MGD	0	01		01	
DAILY AVG	PERMITTED				01	NA	01	NA
NUMBER OF OPERATOR	REPORTED	WW0018247	NUMBER	0	01		01	
CERTIFICATE	PERMITTED				01	NA	01	NA
EXPIRATION OF OPERATOR	REPORTED	09/11/12	DATE	0	01		01	
CERTIFICATE	PERMITTED				01	NA	01	NA
CLASS OF OPERATOR	REPORTED	A	LETTER	0	01		01	
CERTIFICATE	PERMITTED				01	NA	01	NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

Reclaimed water flow from both Walnut Creek WWTP and South Austin Regional WWTP. Walnut Creek transferred reclaimed water 31 days and South Austin Regional WWTP transferred reclaimed water 31 days.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Mike Welch		09 08 07
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
512 972 0101	Greg Meszaros, Director		09 08 07
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY