

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087  
MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865



40B	WQ0010543-011	1	0   9	0   6	15650
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR RECLAIMED WATER TYPE I "800"  
**SEE BACK FOR INSTRUCTIONS AND DEFINITIONS**  
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS **TCEQ COPY**

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
	REPORTED	VALUE	UNITS			03	03
316164024 FEC. COLI DLY AVG	REPORTED	<1	#/100 ML	0 11	2/WEEK	03	GRABPKLOAD
	PERMITTED	20.000					
316164030 FEC. COLI IND GRAB	REPORTED	<1	#/100 ML	0 11	2/WEEK	03	GRABPKLOAD
	PERMITTED	75.000					
500507124 FLOW DLY AVG	REPORTED	0.44	MGD	0 02	CONT	11	CONT
	PERMITTED						
800821024 BOD CARB DLY AVG	REPORTED	<2	MG/L	0 11	2/WEEK	03	GRABPKLOAD
	PERMITTED	5.000					
820796624 TURBIDITY 30DAYAVG	REPORTED	0.56	NTU	0 11	2/WEEK	03	GRABPKLOAD
	PERMITTED	3.000					
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0018247	NUMBER	0 01	NA	01	NA
	PERMITTED						
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	09/11/12	DATE	0 01	NA	01	NA
	PERMITTED						
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	LETTER	0 01	NA	01	NA
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

**COMMENTS AND EXPLANATIONS** (Reference all attachments here)  
 Data represents reclaimed water flow from Walnut Creek WWTP TPDES Permit # 10543-011 EPA ID TX0046981.  
 Walnut Creek WWTP transferred reclaimed water for 18 days.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Mike Welch		0   9   0   7   0   8
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5   1   2   9   7   2   0   1   0   1	Greg Meszaros, Director		0   9   0   7   0   8
AREA CODE	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087  
MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865



40B SYS	WQ0010543-012 PERMIT NUMBER	1 SET	0   9 YEAR	0   6 MO.	15651 EID
------------	--------------------------------	----------	---------------	--------------	--------------

THIS REPORT TO BE USED FOR RECLAIMED WATER TYPE II "900"  
**SEE BACK FOR INSTRUCTIONS AND DEFINITIONS**  
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS **TCEQ COPY**

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE		
	REPORTED	PERMITTED		VALUE	UNITS			
000085342 TRANSFER DAYS MON	REPORTED	PERMITTED	0	01	30	DAY	01	NA
316164024 FEC. COLI DLY AVG	REPORTED	PERMITTED	0	11	<1	#/100 ML	03	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	PERMITTED	0	11	200:000	#/100 ML	03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	PERMITTED	0	02	5.03	MGD	11	CONT
800821024 BOD CARB DLY AVG	REPORTED	PERMITTED	0	11	<2	MG/L	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	0	01	WW0011708	NUMBER	01	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	0	01	12/05/12	DATE	01	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	0	01	B	LETTER	01	NA
	REPORTED	PERMITTED						
	REPORTED	PERMITTED						
	REPORTED	PERMITTED						
	REPORTED	PERMITTED						

COMMENTS AND EXPLANATIONS (Reference all attachments here)  
 Data represents reclaimed water flow from South Austin Regional WWTP TPDES Permit # 10543-012,  
 EPA ID TX0071889

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Randall Swenson	<i>Randall Swenson</i>	0   9   0   7   0   8
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5   1   2   9   7   2   0   1   0   1	Greg Meszaros, Director	<i>Greg Meszaros</i>	0   9   0   7   0   8
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

## MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865



40B SYS	WQ0010543-011 PERMIT NUMBER	1 SET	0   9 YEAR	0   6 MO.	15652 EID
------------	--------------------------------	----------	---------------	--------------	--------------

THIS REPORT TO BE USED FOR **COMBINED TYPE I AND II RECLAIMED WATER**  
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS  
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	REPORTED	PERMITTED			
500507124 FLOW DAILY AVG	REPORTED		0 01		01
	PERMITTED			NA	01 NA
NUMBER OF OPERATOR CERTIFICATE	REPORTED		0 01		01
	PERMITTED			NA	01 NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED		0 01		01
	PERMITTED			NA	01 NA
CLASS OF OPERATOR CERTIFICATE	REPORTED		0 01		01
	PERMITTED			NA	01 NA
	REPORTED				
	PERMITTED				
	REPORTED				
	PERMITTED				
	REPORTED				
	PERMITTED				
	REPORTED				
	PERMITTED				
	REPORTED				
	PERMITTED				
	REPORTED				
	PERMITTED				

**COMMENTS AND EXPLANATIONS** (*Reference all attachments here*)  
Reclaimed water flow from both Walnut Creek WWTP and South Austin Regional WWTP. Walnut Creek transferred reclaimed water 31 days and South Austin Regional WWTP transferred reclaimed water 30 days.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Mike Welch	<i>Mike Welch</i>	0   9   0   7   0   8
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5   1   2   9   7   2   0   1   0   1	Greg Meszaros, Director	<i>Greg Meszaros</i>	0   9   0   7   0   8
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY