

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087  
MONTHLY EFFLUENT REPORT

Page 1 of 3

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865



|     |               |     |      |     |       |
|-----|---------------|-----|------|-----|-------|
| 40B | WQ0010543-011 | 1   | 0 9  | 1 1 | 15650 |
| SYS | PERMIT NUMBER | SET | YEAR | MO. | EID   |

THIS REPORT TO BE USED FOR **RECLAIMED WATER TYPE I "800"**  
 SEE BACK FOR INSTRUCTIONS AND DEFINITIONS  
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS **TCEQ COPY**

| PARAMETER                                | EFFLUENT CONDITION | EFFLUENT CONDITION |          | NO. EX. | FREQUENCY OF ANALYSIS | SAMPLE TYPE |            |
|--|--------------------|--------------------|----------|---------|-----------------------|-------------|------------|
|  |                    | VALUE              | UNITS    |         |                       |             |            |
| 316164024<br>FEC. COLI<br>DLY AVG        | REPORTED           | <1                 | #/100 ML | 0       | 11                    | 03          |            |
|  | PERMITTED          | 20.000             |          | 11      | 2WEEK                 | 03          | GRABPKLOAD |
| 316164030<br>FEC. COLI<br>IND GRAB       | REPORTED           | <1                 | #/100 ML | 0       | 11                    | 03          |            |
|  | PERMITTED          | 75.000             |          | 11      | 2WEEK                 | 03          | GRABPKLOAD |
| 500507124<br>FLOW<br>DLY AVG             | REPORTED           | 0.08               | MGD      | 0       | 02                    | 11          |            |
|  | PERMITTED          |                    |          | 02      | CONT                  | 11          | CONT       |
| 800821024<br>BOD CARB<br>DLY AVG         | REPORTED           | <2                 | MG/L     | 0       | 11                    | 03          |            |
|  | PERMITTED          | 5.000              |          | 11      | 2WEEK                 | 03          | GRABPKLOAD |
| 820796624<br>TURBIDITY<br>30DAYAVG       | REPORTED           | 0.49               | NTU      | 0       | 11                    | 03          |            |
|  | PERMITTED          | 3.000              |          | 11      | 2WEEK                 | 03          | GRABPKLOAD |
| NUMBER<br>OF OPERATOR<br>CERTIFICATE     | REPORTED           | WW0018247          | NUMBER   | 0       | 01                    | 01          |            |
|  | PERMITTED          |                    |          | 01      | NA                    | 01          | NA         |
| EXPIRATION<br>OF OPERATOR<br>CERTIFICATE | REPORTED           | 12/11/12           | DATE     | 0       | 01                    | 01          |            |
|  | PERMITTED          |                    |          | 01      | NA                    | 01          | NA         |
| CLASS<br>OF OPERATOR<br>CERTIFICATE      | REPORTED           | A                  | LETTER   | 0       | 01                    | 01          |            |
|  | PERMITTED          |                    |          | 01      | NA                    | 01          | NA         |
|  | REPORTED           |                    |          |         |                       |             |            |
|  | PERMITTED          |                    |          |         |                       |             |            |
|  | REPORTED           |                    |          |         |                       |             |            |
|  | PERMITTED          |                    |          |         |                       |             |            |

**COMMENTS AND EXPLANATIONS (Reference all attachments here)**  
 Data represents reclaimed water flow from Walnut Creek WWTP TPDES Permit # 10543-011 EPA ID TX0046981.  
 Walnut Creek WWTP transferred reclaimed water for 30days.

|   |                         |                      |                 |
|---|-------------------------|----------------------|-----------------|
| I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE | NAME                    | SIGNATURE            | DATE            |
|   | Mike Welch              | <i>Mike Welch</i>    | 0 9   1 2   0 8 |
| TELEPHONE NUMBER  | PLANT OPERATOR          | PLANT OPERATOR       | YEAR MO. DAY    |
| 5   1   2   9   7   2   0   1   0   1   | Greg Meszaros, Director | <i>Greg Meszaros</i> | 0 9   1 2   0 8 |
| AREA CODE NUMBER  | EXECUTIVE OFFICER       | EXECUTIVE OFFICER    | YEAR MO. DAY    |


# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

## MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-9865

Page 2 of 3



|            |                                |          |             |            |              |
|------------|--------------------------------|----------|-------------|------------|--------------|
| 40B<br>SYS | WQ0010543-012<br>PERMIT NUMBER | 1<br>SET | 0 9<br>YEAR | 1 1<br>MO. | 15851<br>EID |
|------------|--------------------------------|----------|-------------|------------|--------------|

THIS REPORT TO BE USED FOR **RECLAIMED WATER TYPE II "900"**  
 SEE BACK FOR INSTRUCTIONS AND DEFINITIONS  
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS **TCEQ COPY**

| PARAMETER                          | EFFLUENT CONDITION |           |          | NO. EX. | FREQUENCY OF ANALYSIS | SAMPLE TYPE |            |
|------------------------------------|--------------------|-----------|----------|---------|-----------------------|-------------|------------|
|                                    | REPORTED           | VALUE     | UNITS    |         |                       |             |            |
| 000085342<br>TRANSFER DAYS MON     | REPORTED           | 30        | DAY      | 0 01    |                       | 01          |            |
|                                    | PERMITTED          |           |          | 01      | NA                    | 01          | NA         |
| 316164024<br>FEC. COLI DLY AVG     | REPORTED           | <1        | #/100 ML | 0 11    |                       | 03          |            |
|                                    | PERMITTED          | 200.000   |          | 11      | 2/WEEK                | 03          | GRABPKLOAD |
| 316164030<br>FEC. COLI IND GRAB    | REPORTED           | 1         | #/100 ML | 0 11    |                       | 03          |            |
|                                    | PERMITTED          | 800.000   |          | 11      | 2/WEEK                | 03          | GRABPKLOAD |
| 500507124<br>FLOW DLY AVG          | REPORTED           | 1.38      | MGD      | 0 02    |                       | 11          |            |
|                                    | PERMITTED          |           |          | 02      | CONT                  | 11          | CONT       |
| 800821024<br>BOD CARB DLY AVG      | REPORTED           | <2        | MG/L     | 0 11    |                       | 03          |            |
|                                    | PERMITTED          | 15.000    |          | 11      | 2/WEEK                | 03          | GRABPKLOAD |
| NUMBER OF OPERATOR CERTIFICATE     | REPORTED           | WW0011708 | NUMBER   | 0 01    |                       | 01          |            |
|                                    | PERMITTED          |           |          | 01      | NA                    | 01          | NA         |
| EXPIRATION OF OPERATOR CERTIFICATE | REPORTED           | 12/05/12  | DATE     | 0 01    |                       | 01          |            |
|                                    | PERMITTED          |           |          | 01      | NA                    | 01          | NA         |
| CLASS OF OPERATOR CERTIFICATE      | REPORTED           | B         | LETTER   | 0 01    |                       | 01          |            |
|                                    | PERMITTED          |           |          | 01      | NA                    | 01          | NA         |
|                                    | REPORTED           |           |          |         |                       |             |            |
|                                    | PERMITTED          |           |          |         |                       |             |            |
|                                    | REPORTED           |           |          |         |                       |             |            |
|                                    | PERMITTED          |           |          |         |                       |             |            |

COMMENTS AND EXPLANATIONS (Reference all attachments here)  
 Data represents reclaimed water flow from South Austin Regional WWTP TPDES Permit # 10543-012, EPA ID TX0071889

|   |                        |                        |              |
|---|------------------------|------------------------|--------------|
| I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE | NAME                   | SIGNATURE              | DATE         |
|   | Randall Swenson        | <i>Randall Swenson</i> | 0 9 1 2 0 8  |
| TELEPHONE NUMBER  | PLANT OPERATOR         | PLANT OPERATOR         | YEAR MO. DAY |
| 5 1 2 9 7 2 0 1 0 1   | Greg Mezaros, Director | <i>Greg Mezaros</i>    | 0 9 1 2 0 8  |
| NUMBER  | EXECUTIVE OFFICER      | EXECUTIVE OFFICER      | YEAR MO. DAY |

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087  
MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865

Page 3 of 3



|            |                                |          |                     |              |
|------------|--------------------------------|----------|---------------------|--------------|
| 40B<br>SYS | WQ0010543-011<br>PERMIT NUMBER | 1<br>SET | 0 9 1 1<br>YEAR MO. | 15652<br>EID |
|------------|--------------------------------|----------|---------------------|--------------|

THIS REPORT TO BE USED FOR **COMBINED TYPE I AND II RECLAIMED WATER**  
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS  
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

**TCEQ COPY**

| PARAMETER                          | EFFLUENT CONDITION |           | NO. EX. | FREQUENCY OF ANALYSIS | SAMPLE TYPE |
|------------------------------------|--------------------|-----------|---------|-----------------------|-------------|
|                                    | VALUE              | UNITS     |         |                       |             |
| 500507124 FLOW                     | REPORTED           | 1.46      | MGD     | 0 01                  | 01          |
| DAILY AVG                          | PERMITTED          |           |         | 01 NA                 | 01 NA       |
| NUMBER OF OPERATOR CERTIFICATE     | REPORTED           | WW0018247 | NUMBER  | 0 01                  | 01          |
| EXPIRATION OF OPERATOR CERTIFICATE | PERMITTED          |           |         | 01 NA                 | 01 NA       |
| CLASS OF OPERATOR CERTIFICATE      | REPORTED           | 11/12/12  | DATE    | 0 01                  | 01          |
|                                    | PERMITTED          |           |         | 01 NA                 | 01 NA       |
|                                    | REPORTED           | A         | LETTER  | 0 01                  | 01          |
|                                    | PERMITTED          |           |         | 01 NA                 | 01 NA       |
|                                    | REPORTED           |           |         |                       |             |
|                                    | PERMITTED          |           |         |                       |             |
|                                    | REPORTED           |           |         |                       |             |
|                                    | PERMITTED          |           |         |                       |             |
|                                    | REPORTED           |           |         |                       |             |
|                                    | PERMITTED          |           |         |                       |             |
|                                    | REPORTED           |           |         |                       |             |
|                                    | PERMITTED          |           |         |                       |             |
|                                    | REPORTED           |           |         |                       |             |
|                                    | PERMITTED          |           |         |                       |             |

**COMMENTS AND EXPLANATIONS (Reference all attachments here)**  
Reclaimed water flow from both Walnut Creek WWTP and South Austin Regional WWTP. Walnut Creek transferred reclaimed water 30days and South Austin Regional WWTP transferred reclaimed water 30days.

|   |                         |                   |              |
|---|-------------------------|-------------------|--------------|
| I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE | NAME                    | SIGNATURE         | DATE         |
|   | Mike Welch              |                   | 0 9 1 2 0 8  |
| TELEPHONE NUMBER  | PLANT OPERATOR          | PLANT OPERATOR    | YEAR MO. DAY |
| 5 1 2 9 7 2 0 1 0 1   | Greg Meszaros, Director |                   | 0 9 1 2 0 8  |
| NUMBER  | EXECUTIVE OFFICER       | EXECUTIVE OFFICER | YEAR MO. DAY |