

DMR Copy of Record

Permit

Permit #: **TX0034207**
Major: ☒

Permittee: AUSTIN,CITY OF
Permittee Address: 1700' SW INTX USHWY 183/FM 620
AUSTIN, TX 78750

Facility: ANDERSON MILL MUD WWTP
Facility Location: 1700' SW INTX USHWY 183 FM 620
WILLIAMSON COUNTY
AUSTIN, TX 78750

Permitted Feature: 001
External Outfall

Discharge: **001-A**
DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: From **02/01/10** to **02/28/10**

DMR Due Date: **03/20/10**

Status: **NetDMR Validated**

Considerations for Form Completion

P = 2-HOUR PEAK.11459-001

Principal Executive Officer

First Name: Greg
Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sam Typ
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units		
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	6.2					19 - mg/L	10/30 - Ten Per Month	GR - GRAB
					Permit Req.						>=	4 MO MIN					19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.1			=	7.3	12 - SU	12/30 - Twelve Per Month	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	02/DM - Twice Every Month	GR - GRAB
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	21.9			26 - lb/d			=	5	=	7	19 - mg/L	01/07 - Weekly	CP - COMF
					Permit Req.	<=	124 DAILY AV			26 - lb/d			<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L	01/07 - Weekly	CP - COMF
					Value NODI														
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	=	0.9			26 - lb/d			=	0.2	=	0.3	19 - mg/L	01/07 - Weekly	CP - COMF
					Permit Req.	<=	25 DAILY AV			26 - lb/d			<=	3 DAILY AV	<=	7 DAILY MX	19 - mg/L	01/07 - Weekly	CP - COMF
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.47	=	0.69	03 - Mgal/d								99/99 - Continuous	TM - TOTA
					Permit Req.		Req Mon DAILY AV		Req Mon DAILY MX	03 - Mgal/d								99/99 - Continuous	TM - TOTA
					Value NODI														
50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	Sample			=	750	78 - gal/min								99/99 - Continuous	TM - TOTA
					Permit Req.			<=	2063 2HR PEAK	78 - gal/min								99/99 - Continuous	TM - TOTA
					Value NODI														
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Sample					03 - Mgal/d								99/99 - Continuous	TM - TOTA
					Permit Req.	<=	.99 DAILY AV												
					Value NODI														
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample										=	0.09	19 - mg/L	01/01 - Daily	GR - GRAB
					Permit Req.										<=	.1 INST MAX	19 - mg/L	01/01 - Daily	GR - GRAB
					Value NODI														
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample						=	1.09					19 - mg/L	01/01 - Daily	GR - GRAB
					Permit Req.						>=	1 MO MIN					19 - mg/L	01/01 - Daily	GR - GRAB
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	10.5			26 - lb/d			<	2	=	3	19 - mg/L	01/07 - Weekly	CP - COMF
					Permit Req.	<=	58 DAILY AV			26 - lb/d			<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L	01/07 - Weekly	CP - COMF
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

There is no value reported for the "Y-Effluent Gross" because the annual avg is no longer required by the permit. Additionally, the "permit req" stated on the DMR of " ≤ 0.99 Daily Average" is the daily average flow maximum stated in the permit.

Attachments

No attachments.

Report Last Saved By

AUSTIN,CITY OF

User: jane.burazer@ci.austin.tx.us

Name: Jane Burazer

E-Mail: jane.burazer@ci.austin.tx.us

Date/Time: 2010-03-12 09:49 (Time Zone: -06:00)