

DMR Copy of Record

Permit

Permit #: **TX0034207**
Major: ☒

Permittee: AUSTIN,CITY OF
Permittee Address: 1700' SW INTX USHWY 183/FM 620
AUSTIN, TX 78750

Facility: ANDERSON MILL MUD WWTP
Facility Location: 1700' SW INTX USHWY 183 FM 620
WILLIAMSON COUNTY
AUSTIN, TX 78750

Permitted Feature: 001
External Outfall

Discharge: **001-A**
DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: **From 06/01/10 to 06/30/10**

DMR Due Date: **07/20/10**

Status: **NetDMR Validated**

Considerations for Form Completion

P = 2-HOUR PEAK.11459-001

Principal Executive Officer

First Name: Greg
Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading						Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	6.1				19 - mg/L	0	06/30 - Six Per Month	GR - GRAB
					Permit Req.						> =	4 MO MIN				19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.6			=	7.1	12 - SU	06/30 - Six Per Month	GR - GRAB
					Permit Req.						> =	6 MINIMUM			< =	9 MAXIMUM	12 - SU	02/DM - Twice Every Month	GR - GRAB
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	5		26 - lb/d			=	2	=	3	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	< =	124 DAILY AV		26 - lb/d			< =	15 DAILY AV	< =	40 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI														
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	=	2		26 - lb/d			=	1	=	2	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	< =	25 DAILY AV		26 - lb/d			< =	3 DAILY AV	< =	7 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.34	=	0.51	03 - Mgal/d							0	99/99 - Continuous	TM - TOTALZ
					Permit Req.	< =	.99 DAILY AV		Req Mon DAILY MX	03 - Mgal/d								99/99 - Continuous	TM - TOTALZ
					Value NODI														
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample									=	0.06	19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.									< =	.1 INST MAX	19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI														
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample						=	1.11				19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.						> =	1 MO MIN				19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	10		26 - lb/d			<	3	=	7	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	< =	58 DAILY AV		26 - lb/d			< =	7 DAILY AV	< =	17 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN,CITY OF

User: jane.burazer@ci.austin.tx.us
Name: Jane Burazer
E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2010-07-14 11:28 (Time Zone: -05:00)