

DMR Copy of Record

Permit

Permit #:	TX0097870	Permittee:	AUSTIN, CITY OF	Facility:	DESSAU WWTF
Major:	☐	Permittee Address:	1.4M N DESSAU RD&YAGER LANE AUSTIN, TX 78746	Facility Location:	1.4M N DESSAU RD AND YAGER LANE AUSTIN, TX 78746
Permitted Feature:	001 External Outfall	Discharge:	001-A DOMESTIC FACILITY - 001		

Report Dates & Status

Monitoring Period:	From 06/01/10 to 06/30/10	DMR Due Date:	07/20/10	Status:	NetDMR Validated
--------------------	---------------------------	---------------	----------	---------	------------------

Considerations for Form Completion
WQ0012971-001

Principal Executive Officer

First Name:	Greg	Title:	Director	Telephone:	512-972-0101
Last Name:	Meszaros				

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	S
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	6.4					19 - mg/L	0	24/30 - 24 Per Month	G G
					Permit Req.						>=	5 MO MIN					19 - mg/L		01/07 - Weekly	G G
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.7			=	8	12 - SU	0	28/30 - 28 Per Month	G G
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		02/30 - Twice Per Month	G G
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	5			26 - lb/d			=	4	=	10	19 - mg/L	0	01/07 - Weekly	CI CI
					Permit Req.	<=	63 DAILY AV			26 - lb/d			<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L		01/07 - Weekly	CI CI
					Value NODI															
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	1			26 - lb/d			<	1	<	1	19 - mg/L	0	01/07 - Weekly	CI CI
					Permit Req.	<=	13 DAILY AV			26 - lb/d			<=	3 DAILY AV	<=	10 DAILY MX	19 - mg/L		01/07 - Weekly	CI CI
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.13	=	0.15	03 - Mgal/d								0	99/99 - Continuous	TI TI
					Permit Req.	<=	.5 DAILY AV		Req Mon DAILY MX	03 - Mgal/d									99/99 - Continuous	TI TI
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						=	1.1			=	3.5	19 - mg/L	0	01/01 - Daily	G G
					Permit Req.						>=	1 MO MIN			<=	4 MO MAX	19 - mg/L		01/01 - Daily	G G
					Value NODI															
X 51040	E. coli	1 - Effluent Gross	0	--	Sample								<	7	=	248	30 - MPN/100mL	0	01/07 - Weekly	G G
					Permit Req.								<=	120 DAILY AV	<=	374 DAILY MX	3Z - CFU/100mL		01/07 - Weekly	G G
					Value NODI															
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	4			26 - lb/d			=	4	=	4	19 - mg/L	0	01/07 - Weekly	CI CI
					Permit Req.	<=	42 DAILY AV			26 - lb/d			<=	10 DAILY AV	<=	25 DAILY MX	19 - mg/L		01/07 - Weekly	CI CI
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Ss Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknow
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	☒

Comments

E.coli Results in MPN/100mLs and NOT CFU/100mLs.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us
Name: Jane Burazer
E-Mail: jane.burazer@ci.austin.tx.us

Date/Time: 2010-07-14 11:31 (Time Zone: -05:00)