

DMR Copy of Record

Permit

Permit #: TX0101532
Major: ☒

Permittee: AUSTIN, CITY OF
Permittee Address: 0.25MI W OF INTX GILES RD & AUSTIN, TX 78701
Discharge: 001-A DOMESTIC FACILITY - 001

Facility: HARRIS BRANCH WWTP
Facility Location: 0.25MI W OF INTX GILES RD BOYCE LN AUSTIN, TX 78701

Permitted Feature: 001 External Outfall

Report Dates & Status

Monitoring Period: From 04/01/10 to 04/30/10

DMR Due Date: 05/20/10

Status: NetDMR Validated

Considerations for Form Completion

INTERIM I PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.80 MGD FACILITIES.

Principal Executive Officer

First Name: Greg
Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units		
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	8					19 - mg/L	01/07 - Weekly	GR - GRAB
					Permit Req.						>=	5 MO MIN					19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.8			=	7.3	12 - SU	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	01/30 - Monthly	GR - GRAB
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	2			26 - lb/d			=	1		2	19 - mg/L	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	17 DAILY AV			26 - lb/d			<=	5 DAILY AV	<=	30 SINGGRAB	19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI														
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	=	0.1			26 - lb/d			<	1	<	1	19 - mg/L	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	6.7 DAILY AV			26 - lb/d			<=	2 DAILY AV	<=	15 SINGGRAB	19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI														
00665	Phosphorus, total (as P)	1 - Effluent Gross	0	--	Sample	=	0.4			26 - lb/d			<	1	<	1	19 - mg/L	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	3.3 DAILY AV			26 - lb/d			<=	1 DAILY AV	<=	6 SINGGRAB	19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.2	=	0.3	03 - Mgal/d								01/01 - Daily	IN - INSTAN
					Permit Req.	<=	4 DAILY AV		Req Mon DAILY MX	03 - Mgal/d								05/WK - Five Per Week	IN - INSTAN
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						=	1.1			=	2.7	19 - mg/L	01/01 - Daily	GR - GRAB
					Permit Req.						>=	1 MO MIN			<=	4 MO MAX	19 - mg/L	05/WK - Five Per Week	GR - GRAB
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	4			26 - lb/d			<	2	=	4	19 - mg/L	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	17 DAILY AV			26 - lb/d			<=	5 DAILY AV	<=	30 SINGGRAB	19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

As per new permit, EColi samples to be collected once per month. EColi samples collected on: 4/1/10, 4/8/10/, 4/15/10, 4/21/10, 4/29/10. Daily Average <13, Daily Max 45 CFU/100mL, frequency 01/07 gr.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us
Name: Jane Burazer
E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2010-07-15 14:45 (Time Zone: -05:00)