

DMR Copy of Record

Permit

Permit #: **TX0067466**
Major: ☐

Permittee: AUSTIN, CITY OF
Permittee Address: 8250 CITATION AVE, 2400F E. FMR
AUSTIN, TX 787670000

Facility: THOROUGHbred FARMS WWTP
Facility Location: 8250 CITATION AVE, 2400F E. FMR
973 & 2800F S FMR 812, TRAVIS
AUSTIN, TX 787670000

Permitted Feature: 001
External Outfall

Discharge: **001-A**
DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: **From 01/01/10 to 01/31/10**

DMR Due Date: **02/20/10**

Status: **NetDMR Validated**

Considerations for Form Completion
14459-001

Principal Executive Officer

First Name: Greg
Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	6.7					19 - mg/L	0	08/30 - Eight Every Month	GR - GRAB
					Permit Req.						>=	2 MO MIN					19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	<	0.5			26 - lb/d			<	2	=	3	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV			26 - lb/d			<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7			=	7.5	12 - SU	0	21/30 - 21 Per Month	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		01/30 - Monthly	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	1			26 - lb/d			=	5	=	10	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV			26 - lb/d			<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.04	=	0.132	03 - Mgal/d								0	05/WK - Five Per Week	IN - INSTAN
					Permit Req.	<=	.065 DAILY AV		Req Mon DAILY MX	03 - Mgal/d									05/WK - Five Per Week	IN - INSTAN
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						=	1.2			=	2.1	19 - mg/L	0	05/WK - Five Per Week	GR - GRAB
					Permit Req.						>=	1 MO MIN			<=	4 MO MAX	19 - mg/L		05/WK - Five Per Week	GR - GRAB
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

The week of 1/3/10 to 1/9/10: BOD sample collected on 1/5/10 was reported as a Laboratory Error due to a BOD standard failure. Since the permit states that the monthly avg consist of a minimum of four measurements, the arithmetic avg of the four most recent measurements was used as the January daily avg on the DMR.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us
Name: Jane Burazer
E-Mail: jane.burazer@ci.austin.tx.us

Date/Time: 2010-02-12 12:05 (Time Zone: -06:00)