

DMR Copy of Record

Permit

Permit #: **TX0067466**

Major: ☐

Permitted Feature: 001
External Outfall

Permittee: AUSTIN, CITY OF

Permittee Address: 8250 CITATION AVE, 2400F E. FMR
AUSTIN, TX 787670000

Discharge: **001-A**
DOMESTIC FACILITY - 001

Facility: THOROUGHbred FARMS WWTP

Facility Location: 8250 CITATION AVE, 2400F E. FMR 973
AUSTIN, TX 787670000

Report Dates & Status

Monitoring Period: **From 03/01/10 to 03/31/10**

DMR Due Date: **04/20/10**

Status: **NetDMR Validated**

Considerations for Form Completion

14459-001

Principal Executive Officer

First Name: Greg

Title: Director

Telephone: 512-972-0101

Last Name: Meszaros

No Data Indicator (NODI)

Form NODI: --

Parameter Code	Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					Units	# of Ex.	Frequency of Analysis	Sample Type
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3			
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample					=	6.8					19 - mg/L	15/30 - 15 Per Month	GR - GRAB
					Permit Req.					>=	2 MO MIN					19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI													
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	=	0.9		26 - lb/d			=	5		8	19 - mg/L	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV		26 - lb/d			<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI													
00400	pH	1 - Effluent Gross	0	--	Sample					=	7				7.5	12 - SU	21/30 - 21 Per Month	GR - GRAB
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	01/30 - Monthly	GR - GRAB
					Value NODI													
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	3.6		26 - lb/d			=	20		30	19 - mg/L	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV		26 - lb/d			<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.026	=	0.041	03 - Mgal/d							05/WK - Five Per Week	IN - INSTAN
					Permit Req.	<=	.065 DAILY AV		Req Mon DAILY MX	03 - Mgal/d							05/WK - Five Per Week	IN - INSTAN
					Value NODI													
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	1.1				1.9	19 - mg/L	05/WK - Five Per Week	GR - GRAB
					Permit Req.					>=	1 MO MIN			<=	4 MO MAX	19 - mg/L	05/WK - Five Per Week	GR - GRAB
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us

Date/Time:

2010-04-13 18:19 (Time Zone: -05:00)

Name: Jane Burazer

E-Mail: jane.burazer@ci.austin.tx.us