

DMR Copy of Record

Permit

Permit #: TX0067466

Major: ☐

Permitted Feature: 001
External Outfall

Permittee: AUSTIN, CITY OF

Permittee Address: 8250 CITATION AVE, 2400F E. FMR
AUSTIN, TX 787670000

Discharge: 001-A
DOMESTIC FACILITY - 001

Facility: THOROUGHbred FARMS WWTP

Facility Location: 8250 CITATION AVE, 2400F E. FMR 973
AUSTIN, TX 787670000

Report Dates & Status

Monitoring Period: From 09/01/10 to 09/30/10

DMR Due Date: 10/20/10

Status: NetDMR Validated

Considerations for Form Completion

14459-001

Principal Executive Officer

First Name: Greg

Title: Director

Telephone: 512-972-0101

Last Name: Meszaros

No Data Indicator (NODI)

Form NODI: --

Parameter Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units		
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample					=	5.6					19 - mg/L	12/30 - Twelve Per Month	GR - GRAB
					Permit Req.					>=	2 MO MIN					19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI													
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	<	1		26 - lb/d			<	2	<	2	19 - mg/L	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV		26 - lb/d			<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI													
00400	pH	1 - Effluent Gross	0	--	Sample					=	7			=	8	12 - SU	19/30 - 19 Per Month	GR - GRAB
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	01/30 - Monthly	GR - GRAB
					Value NODI													
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	1		26 - lb/d			=	2	=	4	19 - mg/L	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV		26 - lb/d			<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.051	=	0.091	03 - Mgal/d							05/WK - Five Per Week	IN - INSTAN
					Permit Req.	<=	.065 DAILY AV		Req Mon DAILY MX	03 - Mgal/d							05/WK - Five Per Week	IN - INSTAN
					Value NODI													
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	1			=	2.2	19 - mg/L	21/30 - 21 Per Month	GR - GRAB
					Permit Req.					>=	1 MO MIN			<=	4 MO MAX	19 - mg/L	05/WK - Five Per Week	GR - GRAB
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

CI2: For the week of 9/5/10 - 9/11/10, only 4 CI2 samples were collected/analyzed. The permit requires 5 grabs/week.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us

Date/Time:

2010-10-15 16:11 (Time Zone: -05:00)

Name: Jane Burazer

E-Mail: jane.burazer@ci.austin.tx.us