

DMR Copy of Record

Permit

Permit #: TX0124800
Major: ☐

Permittee: AUSTIN, CITY OF
Permittee Address: 4800' E INTX BLUE BLUFF RD & AUSTIN, TX 78767

Facility: WILD HORSE RANCH WWTP
Facility Location: 4800' E INTX BLUE BLUFF RD & LINDEL LN, TRAVIS COUNTY AUSTIN, TX 78767

Permitted Feature: 001
External Outfall

Discharge: 001-A
DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: From 02/01/10 to 02/28/10

DMR Due Date: 03/20/10

Status: NetDMR Validated

Considerations for Form Completion

INTERIM PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.99 MGD FACILITIES.WQ0010543-013_____WQ0010543-013

Principal Executive Officer

First Name: Greg
Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter Code	Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units		
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample					=	7.9					19 - mg/L	14/30 - 14 Per Month	GR - GRAB
					Permit Req.					>=	5 MO MIN					19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI													
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.4			=	7.9	12 - SU	15/30 - 15 Per Month	GR - GRAB
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	02/30 - Twice Per Month	GR - GRAB
					Value NODI													
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	<	1.5		26 - lb/d			<	0.8	=	1	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	31 DAILY AV		26 - lb/d			<=	5 DAILY AV	<=	20 DAILY MX	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Value NODI													
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	=	0.6		26 - lb/d			=	0.4	=	1	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	13 DAILY AV		26 - lb/d			<=	2 DAILY AV	<=	7 DAILY MX	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Value NODI													
00665	Phosphorus, total (as P)	1 - Effluent Gross	0	--	Sample	=	0.2		26 - lb/d			=	0.09	=	0.2	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	6.3 DAILY AV		26 - lb/d			<=	1 DAILY AV	<=	4 DAILY MX	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.27	=	0.56	03 - Mgal/d							99/99 - Continuous	TM - TOTALZ
					Permit Req.	<=	.75 DAILY AV		Req Mon DAILY MX	03 - Mgal/d							99/99 - Continuous	TM - TOTALZ
					Value NODI													
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample							<	1	<	2	3Z - CFU/100mL	01/01 - Daily	GR - GRAB
					Permit Req.							<=	200 DAILY AV	<=	400 7 DA AVG	3Z - CFU/100mL	01/01 - Daily	GR - GRAB
					Value NODI													
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	3.8		26 - lb/d			<	2	<	2	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	31 DAILY AV		26 - lb/d			<=	5 DAILY AV	<=	20 DAILY MX	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us
Name: Jane Burazer
E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2010-03-12 10:07 (Time Zone: -06:00)