

DMR Copy of Record

Permit

|                    |                          |                    |                                               |                    |                                                                        |
|--------------------|--------------------------|--------------------|-----------------------------------------------|--------------------|------------------------------------------------------------------------|
| Permit #:          | TX0124800                | Permittee:         | AUSTIN, CITY OF                               | Facility:          | WILD HORSE RANCH WWTP                                                  |
| Major:             | <input type="checkbox"/> | Permittee Address: | 4800' E INTX BLUE BLUFF RD & AUSTIN, TX 78767 | Facility Location: | 4800' E INTX BLUE BLUFF RD & LINDEL LN, TRAVIS COUNTY AUSTIN, TX 78767 |
| Permitted Feature: | 001<br>External Outfall  | Discharge:         | 001-A<br>DOMESTIC FACILITY - 001              |                    |                                                                        |

Report Dates & Status

|                    |                           |               |          |         |                  |
|--------------------|---------------------------|---------------|----------|---------|------------------|
| Monitoring Period: | From 07/01/10 to 07/31/10 | DMR Due Date: | 08/20/10 | Status: | NetDMR Validated |
|--------------------|---------------------------|---------------|----------|---------|------------------|

Considerations for Form Completion

INTERIM PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.99 MGD FACILITIES.

Principal Executive Officer

|             |          |        |          |            |              |
|-------------|----------|--------|----------|------------|--------------|
| First Name: | Greg     | Title: | Director | Telephone: | 972-972-0101 |
| Last Name:  | Meszaros |        |          |            |              |

No Data Indicator (NODI)

Form NODI: --

| Code    | Parameter Name                           | Monitoring Location | Season # | Param. NODI |             | Quantity or Loading |              |             |                  |             | Quality or Concentration |           |             |              |             |              |                | # of Ex. | Frequency of Analysis   | S  |
|---------|------------------------------------------|---------------------|----------|-------------|-------------|---------------------|--------------|-------------|------------------|-------------|--------------------------|-----------|-------------|--------------|-------------|--------------|----------------|----------|-------------------------|----|
|         |                                          |                     |          |             |             | Qualifier 1         | Value 1      | Qualifier 2 | Value 2          | Units       | Qualifier 1              | Value 1   | Qualifier 2 | Value 2      | Qualifier 3 | Value 3      | Units          |          |                         |    |
| 00300   | Oxygen, dissolved (DO)                   | 1 - Effluent Gross  | 0        | --          | Sample      |                     |              |             |                  | =           |                          | 7         |             |              |             |              | 19 - mg/L      | 0        | 14/30 - 14 Per Month    | G  |
|         |                                          |                     |          |             | Permit Req. |                     |              |             |                  | >=          |                          | 5 MO MIN  |             |              |             |              | 19 - mg/L      |          | 01/07 - Weekly          | G  |
|         |                                          |                     |          |             | Value NODI  |                     |              |             |                  |             |                          |           |             |              |             |              |                |          |                         |    |
| 00400   | pH                                       | 1 - Effluent Gross  | 0        | --          | Sample      |                     |              |             |                  | =           |                          | 6.4       |             |              | =           | 7.2          | 12 - SU        | 0        | 15/30 - 15 Per Month    | G  |
|         |                                          |                     |          |             | Permit Req. |                     |              |             |                  | >=          |                          | 6 MINIMUM |             |              | <=          | 9 MAXIMUM    | 12 - SU        |          | 02/30 - Twice Per Month | G  |
|         |                                          |                     |          |             | Value NODI  |                     |              |             |                  |             |                          |           |             |              |             |              |                |          |                         |    |
| 00530   | Solids, total suspended                  | 1 - Effluent Gross  | 0        | --          | Sample      | =                   | 1            |             |                  | 26 - lb/d   |                          |           | =           | 1            | =           | 2            | 19 - mg/L      | 0        | 01/07 - Weekly          | Cf |
|         |                                          |                     |          |             | Permit Req. | <=                  | 31 DAILY AV  |             |                  | 26 - lb/d   |                          |           | <=          | 5 DAILY AV   | <=          | 20 DAILY MX  | 19 - mg/L      |          | 01/07 - Weekly          | Cf |
|         |                                          |                     |          |             | Value NODI  |                     |              |             |                  |             |                          |           |             |              |             |              |                |          |                         |    |
| 00610   | Nitrogen, ammonia total (as N)           | 1 - Effluent Gross  | 0        | --          | Sample      | <                   | 1            |             |                  | 26 - lb/d   |                          |           | <           | 1            | <           | 1            | 19 - mg/L      | 0        | 01/07 - Weekly          | Cf |
|         |                                          |                     |          |             | Permit Req. | <=                  | 13 DAILY AV  |             |                  | 26 - lb/d   |                          |           | <=          | 2 DAILY AV   | <=          | 10 DAILY MX  | 19 - mg/L      |          | 01/07 - Weekly          | Cf |
|         |                                          |                     |          |             | Value NODI  |                     |              |             |                  |             |                          |           |             |              |             |              |                |          |                         |    |
| 00665   | Phosphorus, total (as P)                 | 1 - Effluent Gross  | 0        | --          | Sample      | <                   | 0.1          |             |                  | 26 - lb/d   |                          |           | <           | 1            | <           | 1            | 19 - mg/L      | 0        | 01/07 - Weekly          | Cf |
|         |                                          |                     |          |             | Permit Req. | <=                  | 6.3 DAILY AV |             |                  | 26 - lb/d   |                          |           | <=          | 1 DAILY AV   | <=          | 4 DAILY MX   | 19 - mg/L      |          | 01/07 - Weekly          | Cf |
|         |                                          |                     |          |             | Value NODI  |                     |              |             |                  |             |                          |           |             |              |             |              |                |          |                         |    |
| 50050   | Flow, in conduit or thru treatment plant | 1 - Effluent Gross  | 0        | --          | Sample      | =                   | 0.18         | =           | 0.28             | 03 - Mgal/d |                          |           |             |              |             |              |                | 0        | 99/99 - Continuous      | Tf |
|         |                                          |                     |          |             | Permit Req. | <=                  | .75 DAILY AV |             | Req Mon DAILY MX | 03 - Mgal/d |                          |           |             |              |             |              |                |          | 99/99 - Continuous      | Tf |
|         |                                          |                     |          |             | Value NODI  |                     |              |             |                  |             |                          |           |             |              |             |              |                |          |                         |    |
| X 51040 | E. coli                                  | 1 - Effluent Gross  | 0        | --          | Sample      |                     |              |             |                  |             |                          |           | <           | 1            | =           | 3            | 30 - MPN/100mL | 0        | 01/01 - Daily           | G  |
|         |                                          |                     |          |             | Permit Req. |                     |              |             |                  |             |                          |           | <=          | 120 DAILY AV | <=          | 374 DAILY MX | 3Z - CFU/100mL |          | 01/01 - Daily           | G  |
|         |                                          |                     |          |             | Value NODI  |                     |              |             |                  |             |                          |           |             |              |             |              |                |          |                         |    |
| 80082   | BOD, carbonaceous, 05 day, 20 C          | 1 - Effluent Gross  | 0        | --          | Sample      | <                   | 3            |             |                  | 26 - lb/d   |                          |           | <           | 2            | <           | 2            | 19 - mg/L      | 0        | 01/07 - Weekly          | Cf |
|         |                                          |                     |          |             | Permit Req. | <=                  | 31 DAILY AV  |             |                  | 26 - lb/d   |                          |           | <=          | 5 DAILY AV   | <=          | 20 DAILY MX  | 19 - mg/L      |          | 01/07 - Weekly          | Cf |
|         |                                          |                     |          |             | Value NODI  |                     |              |             |                  |             |                          |           |             |              |             |              |                |          |                         |    |

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and S Type.

Edit Check Errors

| Parameter |         | Monitoring Location | Field | Type | Description                                                                                                                                                         | Acknow                              |
|-----------|---------|---------------------|-------|------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|
| Code      | Name    |                     |       |      |                                                                                                                                                                     |                                     |
| 51040     | E. coli | 1 - Effluent Gross  | Units | Soft | The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3) | <input checked="" type="checkbox"/> |

Comments

E.coli Results in MPN/100mLs and NOT CFU/100mLs.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us  
Name: Jane Burazer  
E-Mail: jane.burazer@ci.austin.tx.us

Date/Time: 2010-08-12 16:20 (Time Zone: -05:00)