

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

## MONTHLY EFFLUENT REPORT

Page 1 of 3

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865



|            |                                |          |                           |              |
|------------|--------------------------------|----------|---------------------------|--------------|
| 40B<br>SYS | WQ0010543-011<br>PERMIT NUMBER | 1<br>SET | 1   0   1   2<br>YEAR MO. | 15650<br>EID |
|------------|--------------------------------|----------|---------------------------|--------------|

THIS REPORT TO BE USED FOR **RECLAIMED WATER TYPE I "800"**  
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS  
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

**TCEQ COPY**

| PARAMETER                                | EFFLUENT CONDITION |           |          | NO.<br>EX. | FREQUENCY<br>OF ANALYSIS |        | SAMPLE<br>TYPE |            |
|--|--------------------|-----------|----------|------------|--------------------------|--------|----------------|------------|
|  |                    | VALUE     | UNITS    |            |                          |        |                |            |
| 316164024<br>FEC. COLI<br>DLY AVG        | REPORTED           | <2        | #/100 ML | 0          | 11                       |        | 03             |            |
|  | PERMITTED          | 20.000    |          |            | 11                       | 2/WEEK | 03             | GRABPKLOAD |
| 316164030<br>FEC. COLI<br>ND GRAB        | REPORTED           | <2        | #/100 ML | 0          | 11                       |        | 03             |            |
|  | PERMITTED          | 75.000    |          |            | 11                       | 2/WEEK | 03             | GRABPKLOAD |
| 500507124<br>FLOW<br>DLY AVG             | REPORTED           | 0.25      | MGD      | 0          | 02                       |        | 11             |            |
|  | PERMITTED          |           |          |            | 02                       | CONT   | 11             | CONT       |
| 800821024<br>BOD CARB<br>DLY AVG         | REPORTED           | <2.2      | MG/L     | 0          | 11                       |        | 03             |            |
|  | PERMITTED          | 5.000     |          |            | 11                       | 2/WEEK | 03             | GRABPKLOAD |
| 820796624<br>TURBIDITY<br>30DAYAVG       | REPORTED           | 1.95      | NTU      | 0          | 11                       |        | 03             |            |
|  | PERMITTED          | 3.000     |          |            | 11                       | 2/WEEK | 03             | GRABPKLOAD |
| NUMBER<br>OF OPERATOR<br>CERTIFICATE     | REPORTED           | WW0018247 | NUMBER   | 0          | 01                       |        | 01             |            |
|  | PERMITTED          |           |          |            | 01                       | NA     | 01             | NA         |
| EXPIRATION<br>OF OPERATOR<br>CERTIFICATE | REPORTED           | 12/11/12  | DATE     | 0          | 01                       |        | 01             |            |
|  | PERMITTED          |           |          |            | 01                       | NA     | 01             | NA         |
| CLASS<br>OF OPERATOR<br>CERTIFICATE      | REPORTED           | A         | LETTER   | 0          | 01                       |        | 01             |            |
|  | PERMITTED          |           |          |            | 01                       | NA     | 01             | NA         |
|  | REPORTED           |           |          |            |                          |        |                |            |
|  | PERMITTED          |           |          |            |                          |        |                |            |
|  | REPORTED           |           |          |            |                          |        |                |            |
|  | PERMITTED          |           |          |            |                          |        |                |            |

COMMENTS AND EXPLANATIONS (Reference all attachments here)

Data represents reclaimed water flow from Walnut Creek WWTP TPDES Permit # 10543-011 EPA ID TX0046981.  
Walnut Creek WWTP transferred reclaimed water for 24 days.

|   |           |               |                         |                   |                                       |
|---|-----------|---------------|-------------------------|-------------------|---------------------------------------|
| I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE |           |               | NAME                    | SIGNATURE         | DATE                                  |
|   |           |               | Mike Welch              |                   | 1   1   0   1   1   8<br>YEAR MO. DAY |
| TELEPHONE NUMBER  |           |               | PLANT OPERATOR          | PLANT OPERATOR    | YEAR MO. DAY                          |
| 5   1   2   | 9   7   2 | 0   1   0   1 | Greg Meszaros, Director |                   | 1   1   0   1   1   8<br>YEAR MO. DAY |
| AREA CODE   | NUMBER    |               | EXECUTIVE OFFICER       | EXECUTIVE OFFICER | YEAR MO. DAY                          |

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

## MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865

Page 2 of 3



|            |                                |          |               |              |              |
|------------|--------------------------------|----------|---------------|--------------|--------------|
| 40B<br>SYS | WQ0010543-012<br>PERMIT NUMBER | 1<br>SET | 1   0<br>YEAR | 1   2<br>MO. | 15651<br>EID |
|------------|--------------------------------|----------|---------------|--------------|--------------|

THIS REPORT TO BE USED FOR **RECLAIMED WATER TYPE II "900"**

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

**TCEQ COPY**

| PARAMETER                                | EFFLUENT CONDITION |           |          | NO.<br>EX. | FREQUENCY<br>OF ANALYSIS |        | SAMPLE<br>TYPE |            |
|--|--------------------|-----------|----------|------------|--------------------------|--------|----------------|------------|
|  |                    | VALUE     | UNITS    |            |                          |        |                |            |
| 000085342<br>TRANSFER<br>DAYS MON        | REPORTED           | 31        | DAY      | 0          | 01                       |        | 01             |            |
|  | PERMITTED          |           |          |            | 01                       | NA     | 01             | NA         |
| 316164024<br>FEC. COLI<br>DLY AVG        | REPORTED           | <2        | #/100 ML | 0          | 11                       |        | 03             |            |
|  | PERMITTED          | 200.000   |          |            | 11                       | 2/WEEK | 03             | GRABPKLOAD |
| 316164030<br>FEC. COLI<br>IND GRAB       | REPORTED           | 9         | #/100 ML | 0          | 11                       |        | 03             |            |
|  | PERMITTED          | 800.000   |          |            | 11                       | 2/WEEK | 03             | GRABPKLOAD |
| 500507124<br>FLOW<br>DLY AVG             | REPORTED           | 2.75      | MGD      | 0          | 02                       |        | 11             |            |
|  | PERMITTED          |           |          |            | 02                       | CONT   | 11             | CONT       |
| 800821024<br>BOD CARB<br>DLY AVG         | REPORTED           | <2.0      | MG/L     | 0          | 11                       |        | 03             |            |
|  | PERMITTED          | 15.000    |          |            | 11                       | 2/WEEK | 03             | GRABPKLOAD |
| NUMBER<br>OF OPERATOR<br>CERTIFICATE     | REPORTED           | WW0011708 | NUMBER   | 0          | 01                       |        | 01             |            |
|  | PERMITTED          |           |          |            | 01                       | NA     | 01             | NA         |
| EXPIRATION<br>OF OPERATOR<br>CERTIFICATE | REPORTED           | 12/05/12  | DATE     | 0          | 01                       |        | 01             |            |
|  | PERMITTED          |           |          |            | 01                       | NA     | 01             | NA         |
| CLASS<br>OF OPERATOR<br>CERTIFICATE      | REPORTED           | B         | LETTER   | 0          | 01                       |        | 01             |            |
|  | PERMITTED          |           |          |            | 01                       | NA     | 01             | NA         |
|  | REPORTED           |           |          |            |                          |        |                |            |
|  | PERMITTED          |           |          |            |                          |        |                |            |
|  | REPORTED           |           |          |            |                          |        |                |            |
|  | PERMITTED          |           |          |            |                          |        |                |            |
|  | REPORTED           |           |          |            |                          |        |                |            |
|  | PERMITTED          |           |          |            |                          |        |                |            |

COMMENTS AND EXPLANATIONS (Reference all attachments here)

Data represents reclaimed water flow from South Austin Regional WWTP TPDES Permit # 10543-012, EPA ID TX0071889

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE

|                                       |                         |                   |                       |
|---------------------------------------|-------------------------|-------------------|-----------------------|
|                                       | NAME                    | SIGNATURE         | DATE                  |
|                                       | Randall Swenson         |                   | 1   1   0   1   1   8 |
| TELEPHONE NUMBER                      | PLANT OPERATOR          | PLANT OPERATOR    | YEAR MO. DAY          |
| 5   1   2   9   7   2   0   1   0   1 | Greg Meszaros, Director |                   | 1   1   0   1   1   8 |
| NUMBER                                | EXECUTIVE OFFICER       | EXECUTIVE OFFICER | YEAR MO. DAY          |



# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

## MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865

Page 3 of 3



|            |                                |          |                           |              |
|------------|--------------------------------|----------|---------------------------|--------------|
| 40B<br>SYS | WQ0010543-011<br>PERMIT NUMBER | 1<br>SET | 1   0   1   2<br>YEAR MO. | 15652<br>EID |
|------------|--------------------------------|----------|---------------------------|--------------|

THIS REPORT TO BE USED FOR **COMBINED TYPE I AND II RECLAIMED WATER**  
**SEE BACK FOR INSTRUCTIONS AND DEFINITIONS**  
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

**TCEQ COPY**

| PARAMETER                                | EFFLUENT CONDITION |           |        | NO.<br>EX. | FREQUENCY<br>OF ANALYSIS |    | SAMPLE<br>TYPE |    |
|--|--------------------|-----------|--------|------------|--------------------------|----|----------------|----|
|  |                    | VALUE     | UNITS  |            |                          |    |                |    |
| 500507124<br>FLOW                        | REPORTED           | 3.00      | MGD    | 0          | 01                       |    | 01             |    |
| DAILY AVG                                | PERMITTED          |           |        |            | 01                       | NA | 01             | NA |
| NUMBER<br>OF OPERATOR<br>CERTIFICATE     | REPORTED           | WW0018247 | NUMBER | 0          | 01                       |    | 01             |    |
| EXPIRATION<br>OF OPERATOR<br>CERTIFICATE | PERMITTED          |           |        |            | 01                       | NA | 01             | NA |
| CLASS<br>OF OPERATOR<br>CERTIFICATE      | REPORTED           | 12/11/12  | DATE   | 0          | 01                       |    | 01             |    |
|  | PERMITTED          |           |        |            | 01                       | NA | 01             | NA |
|  | REPORTED           | A         | LETTER | 0          | 01                       |    | 01             |    |
|  | PERMITTED          |           |        |            | 01                       | NA | 01             | NA |
|  | REPORTED           |           |        |            |                          |    |                |    |
|  | PERMITTED          |           |        |            |                          |    |                |    |
|  | REPORTED           |           |        |            |                          |    |                |    |
|  | PERMITTED          |           |        |            |                          |    |                |    |
|  | REPORTED           |           |        |            |                          |    |                |    |
|  | PERMITTED          |           |        |            |                          |    |                |    |
|  | REPORTED           |           |        |            |                          |    |                |    |
|  | PERMITTED          |           |        |            |                          |    |                |    |
|  | REPORTED           |           |        |            |                          |    |                |    |
|  | PERMITTED          |           |        |            |                          |    |                |    |
|  | REPORTED           |           |        |            |                          |    |                |    |
|  | PERMITTED          |           |        |            |                          |    |                |    |
|  | REPORTED           |           |        |            |                          |    |                |    |
|  | PERMITTED          |           |        |            |                          |    |                |    |

**COMMENTS AND EXPLANATIONS** (Reference all attachments here)

Reclaimed water flow from both Walnut Creek WWTP and South Austin Regional WWTP. Walnut Creek transferred reclaimed water 24 days and South Austin Regional WWTP transferred reclaimed water 31 days.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE

|                                       |                         |                   |                       |
|---------------------------------------|-------------------------|-------------------|-----------------------|
|                                       | NAME                    | SIGNATURE         | DATE                  |
|                                       | Mike Welch              |                   | 1   1   0   1   1   8 |
| TELEPHONE NUMBER                      | PLANT OPERATOR          | PLANT OPERATOR    | YEAR MO. DAY          |
| 5   1   2   9   7   2   0   1   0   1 | Greg Meszaros, Director |                   | 1   1   0   1   1   8 |
| NUMBER                                | EXECUTIVE OFFICER       | EXECUTIVE OFFICER | YEAR MO. DAY          |