


TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT

Page 1 of 3

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B	WQ0010543-011	1	1 0	1 1	15650
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR **RECLAIMED WATER TYPE I "800"**
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS **TCEQ COPY**

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
	REPORTED	VALUE	UNITS				
316164024 FEC. COLI DLY AVG	REPORTED	<1	#/100 ML	0	11	03	
	PERMITTED	20.000			11	2/WEEK	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	2	#/100 ML	0	11	03	
	PERMITTED	75.000			11	2/WEEK	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	0.20	MGD	0	02	11	
	PERMITTED				02	CONT	CONT
800821024 BOD CARB DLY AVG	REPORTED	<2.1	MG/L	0	11	03	
	PERMITTED	5.000			11	2/WEEK	GRABPKLOAD
820796624 TURBIDITY 30DAYAVG	REPORTED	0.98	NTU	0	11	03	
	PERMITTED	3.000			11	2/WEEK	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0018247	NUMBER	0	01	01	
	PERMITTED				01	NA	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	12/11/12	DATE	0	01	01	
	PERMITTED				01	NA	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	LETTER	0	01	01	
	PERMITTED				01	NA	NA
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

COMMENTS AND EXPLANATIONS (Reference all attachments here)
Data represents reclaimed water flow from Walnut Creek WWTP TPDES Permit # 10543-011 EPA ID TX0046981.
Walnut Creek WWTP transferred reclaimed water for 30 days.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE		
	Mike Welch		1	1	0
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	1	1	0
5 1 2	Greg Meszaros, Director		1	1	0
9 7 2	EXECUTIVE OFFICER	EXECUTIVE OFFICER	1	1	0
0 1 0 1			1	1	0
AREA CODE	NUMBER		1	1	0
			1	1	0

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT

**AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865**

Page 2 of 3



40B SYS	WQ0010543-012 PERMIT NUMBER	1 SET	1 0 YEAR	1 1 MO.	15651 EID
------------	--------------------------------	----------	---------------	--------------	--------------

THIS REPORT TO BE USED FOR RECLAIMED WATER TYPE II "900"

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE		
	REPORTED	VALUE	UNITS					
000085342 TRANSFER DAYS MON	REPORTED	30	DAY	0	01		01	
	PERMITTED			0	01	NA	01	NA
316164024 FEC. COLI DLY AVG	REPORTED	<3	#/100 ML	0	11		03	
	PERMITTED	200.000		0	11	2/WEEK	03	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	37	#/100 ML	0	11		03	
	PERMITTED	800.000		0	11	2/WEEK	03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	2.95	MGD	0	02		11	
	PERMITTED			0	02	CONT	11	CONT
800821024 BOD CARB DLY AVG	REPORTED	<2	MG/L	0	11		03	
	PERMITTED	15.000		0	11	2/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0011708	NUMBER	0	01		01	
	PERMITTED			0	01	NA	01	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	12/05/12	DATE	0	01		01	
	PERMITTED			0	01	NA	01	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	B	LETTER	0	01		01	
	PERMITTED			0	01	NA	01	NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS (Reference all attachments here)
Data represents reclaimed water flow from South Austin Regional WWTP TPDES Permit # 10543-012, EPA ID TX0071889

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Randall Swenson PLANT OPERATOR	<i>Randall Swenson</i> PLANT OPERATOR	1 1 0 1 1 8 YEAR MO. DAY
TELEPHONE NUMBER	PLANT OPERATOR	EXECUTIVE OFFICER	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1 NUMBER	Greg Meszaros, Director EXECUTIVE OFFICER	<i>Greg Meszaros</i> EXECUTIVE OFFICER	1 1 0 1 1 8 YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT

**AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865**



40B SYS	WQ0010543-011 PERMIT NUMBER	1 SET	1 0 1 1 YEAR MO.	15652 EID
------------	--------------------------------	----------	-----------------------------	--------------

THIS REPORT TO BE USED FOR **COMBINED TYPE I AND II RECLAIMED WATER**
 SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		VALUE	UNITS				
500507124 FLOW DAILY AVG	REPORTED	3.14	MGD	0	01		01
	PERMITTED						01
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0018247	NUMBER	0	01		01
	PERMITTED						01
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	12/11/12	DATE	0	01		01
	PERMITTED						01
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	LETTER	0	01		01
	PERMITTED						01
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

COMMENTS AND EXPLANATIONS (Reference all attachments here)
 Reclaimed water flow from both Walnut Creek WWTP and South Austin Regional WWTP. Walnut Creek transferred reclaimed water 30 days and South Austin Regional WWTP transferred reclaimed water 30 days.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Mike Welch		1 1 0 1 1 8 YEAR MO. DAY
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director		1 1 0 1 1 8 YEAR MO. DAY
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY